



BRACEWELL ENGINEERING, INC.

155 MAST STREET, UNIT 114, MORGAN HILL, CA 95037

(669) 258-5820 FAX (408) 498-7045

www.bracewellengineering.com

July 10, 2023

Mr. Eric Lacy
State Water Resources Control Board-Division of Drinking Water
850 Marina Bay Parkway, Building P, 2nd Floor
Richmond, CA 94804

Re: June 2023 Monthly Report to the Office of Drinking Water
La Honda Water System (County Service Area No. 7), No. CA4100509

Dear Mr. Lacy:

Attached are the monitoring report, the Coliform Reporting Form, and the Monthly Summary of Monitoring for Surface Water Treatment Regulations for the La Honda Water System.

- The monthly distribution system treated water bacteriological sample showed an absence of total coliforms and E. coli.
- Chlorine residuals were maintained as required.
- The quarterly disinfection byproducts monitoring was completed and the TTHM running annual average of 66.5 ug/L was in compliance with its MCL of 80 ug/L and the HAA5 running annual average of 45.3 ug/L was in compliance with its MCL of 60 ug/L.
- The minimum Disinfection CT ratio was 2.9 for a DDW required 1- log removal for Giardia.

Please do not hesitate to contact me if you have any questions.

Respectfully submitted,
BRACEWELL ENGINEERING, INC.

Lloyd W. Bracewell, PhD., RCE
Water System Engineer

cc: San Mateo County, CSA #7
BEI Office

La Honda Water System (CSA No. 7)
 555 County Center, 5th Floor
 Redwood City, CA 94063
 System No. CA4100509

WATER SYSTEM MONITORING REPORT

Water Resources Control Board
 Division of Drinking Water
 850 Marina Bay Parkway, Bldg P
 Richmond, CA 98804

Location			Plant On	Raw Water	Raw Water	Treated Water	Backwash
Parameter			SW Plant	Tank	Flow	Average Flow	Flow
frequency			daily	daily	calculation	calculation	calculation
Units			Y/N	ft	gal/d	gal/d	gal/d
Type				level	flow		flow
High Limit							
Low Limit							
Date	Initials	Time					
6/1/2023			N		2,483	-	642
6/2/2023			N		2,483	-	642
6/3/2023			N		2,483	-	642
6/4/2023			N		2,483	-	642
6/5/2023	KB	1430	N	14.46	2,483	-	642
6/6/2023			Y		34,073	41,833	3,275
6/7/2023			Y		34,073	41,833	3,275
6/8/2023			Y		34,073	41,833	3,275
6/9/2023	KB	1000	Y	14.25	34,073	41,833	3,275
6/10/2023			N		33,551	-	2,867
6/11/2023			Y		33,551	47,900	2,867
6/12/2023	KB	1430	Y	14.50	33,551	47,900	2,867
6/13/2023			Y		51,632	48,100	4,100
6/14/2023	KB	1015	Y	13.26	51,632	48,100	4,100
6/15/2023			N		3,327	-	611
6/16/2023			N		3,327	-	611
6/17/2023			N		3,327	-	611
6/18/2023			N		3,327	-	611
6/19/2023			N		3,327	-	611
6/20/2023			N		3,327	-	611
6/21/2023			N		3,327	-	611
6/22/2023			N		3,327	-	611
6/23/2023	KB	1245	Y	8.21	3,327	27,700	611
6/24/2023			Y		51,372	47,800	4,600
6/25/2023			Y		51,372	47,800	4,600
6/26/2023	KB	1030	Y	14.50	51,372	47,800	4,600
6/27/2023			Y		19,174	39,775	1,844
6/28/2023			Y		19,174	39,775	1,844
6/29/2023			Y		19,174	39,775	1,844
6/30/2023			N		19,174	-	1,844

Min	-	1000	-	8.21	2,483	-	611
Max	-	1430	-	14.50	51,632	48,100	4,600
Average				13.20	20,446	21,659	1,993
Total					613,374	649,758	59,789

La Honda Water System (CSA No. 7)
 555 County Center, 5th Floor
 Redwood City, CA 94063
 System No. CA4100509

WATER SYSTEM MONITORING REPORT

Water Resources Control Board
 Division of Drinking Water
 850 Marina Bay Parkway, Bldg P
 Richmond, CA 98804

Location	Contact Pipe	Contact Pipe
Parameter	Temp	CL2
frequency	weekly	weekly
Units	C	mg/L
Type	Grab	Grab
High Limit		
Low Limit		
Date		
6/1/2023		
6/2/2023		
6/3/2023		
6/4/2023		
6/5/2023	13.8	1.1
6/6/2023		
6/7/2023		
6/8/2023		
6/9/2023		
6/10/2023		
6/11/2023		
6/12/2023	16.7	1.78
6/13/2023		
6/14/2023		
6/15/2023		
6/16/2023		
6/17/2023		
6/18/2023		
6/19/2023		
6/20/2023		
6/21/2023		
6/22/2023		
6/23/2023	16.5	0.76
6/24/2023		
6/25/2023		
6/26/2023	16.6	1.89
6/27/2023		
6/28/2023		
6/29/2023		
6/30/2023		

Min	13.80	0.76
Max	16.70	1.89
Average	15.90	1.38
Total		

La Honda Water System (CSA No. 7)
 555 County Center, 5th Floor
 Redwood City, CA 94063
 System No. CA4100509

WATER SYSTEM MONITORING REPORT

Water Resources Control Board
 Division of Drinking Water
 850 Marina Bay Parkway, Bldg P
 Richmond, CA 98804

Location		TW Storage Tank	TW Storage Tank	TW Storage Tank	TW Storage Tank
Parameter		Level	Temp	pH	cl2 residual
frequency		weekly	weekly	weekly	weekly
units		ft	C	Units	ppm
Type		Visual			
High Limit			17.0	8.50	2.00
Low Limit			6.5	7.50	0.30
Date	Oper. Initials				
6/1/2023	KB	16.3	17.3	8.26	1.09
6/2/2023					
6/3/2023					
6/4/2023					
6/5/2023					
6/6/2023					
6/7/2023					
6/8/2023	KB	14.9	17.7	7.9	0.98
6/9/2023					
6/10/2023					
6/11/2023					
6/12/2023					
6/13/2023					
6/14/2023	KB	22.9	16.4	8.11	0.59
6/15/2023					
6/16/2023					
6/17/2023					
6/18/2023					
6/19/2023					
6/20/2023					
6/21/2023					
6/22/2023					
6/23/2023	KB	17.5	15.7	8.4	0.5
6/24/2023					
6/25/2023					
6/26/2023					
6/27/2023					
6/28/2023					
6/29/2023					
6/30/2023	KB	27.9	17.8	8.43	0.76

Min	-	14.9	15.7	7.90	0.50
Max	-	27.9	17.8	8.43	1.09
Average		19.9	17.0	8.22	0.78
Total					

La Honda Water System (CSA No. 7)
 555 County Center, 5th Floor
 Redwood City, CA 94063
 System No. CA4100509

WATER SYSTEM MONITORING REPORT

Water Resources Control Board
 Division of Drinking Water
 850 Marina Bay Parkway, Bldg P
 Richmond, CA 98804

Location		Routine Sample Site
Parameter		Cl2 Residual
frequency		as needed
units		mg/L
Type		grab
High Limit		
Low Limit		
Date	Oper. Initials	
6/1/2023	KB	0.73
6/2/2023		
6/3/2023		
6/4/2023		
6/5/2023		
6/6/2023		
6/7/2023		
6/8/2023	KB	0.84
6/9/2023		
6/10/2023		
6/11/2023		
6/12/2023		
6/13/2023	KB	0.92
6/14/2023		
6/15/2023		
6/16/2023		
6/17/2023		
6/18/2023		
6/19/2023		
6/20/2023		
6/21/2023		
6/22/2023		
6/23/2023	KB	0.36
6/24/2023		
6/25/2023		
6/26/2023		
6/27/2023		
6/28/2023		
6/29/2023		
6/30/2023	KB	1.09

Min	-	0.36
Max	-	1.09
Average		0.79
Total		

June

CHLORINE RESIDUAL	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE	FREQUENCY
	Old Chlorination Station	AA04577	6/13/23	0.9	mg/L		SM 4500-CI G		0.02		LHW_BAC
COLIFORM MPN	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE	FREQUENCY
	ALPINE CREEK - RAW	AA04576	6/13/23	55.4	MPN/100mL		SM9223B-18		1.0		LHW_BAC
COLIFORM PA	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE	FREQUENCY
	Old Chlorination Station	AA04577	6/13/23	A	P/A		SM9223B-18				LHW_BAC
E COLI MPN	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE	FREQUENCY
	ALPINE CREEK - RAW	AA04576	6/13/23	6.3	MPN/100mL		SM9223B-18		1.0		LHW_BAC
E COLI PA	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE	FREQUENCY
	Old Chlorination Station	AA04577	6/13/23	A	P/A		SM9223B-18				LHW_BAC
HALO ACETI	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE	FREQUENCY
	OLD CHLO...*	AA04578	6/13/23	32	µg/L		EPA 552.2	2	1		LHW_DBP
TTHM	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE	FREQUENCY
	OLD CHLO...*	AA04578	6/13/23	40	µg/L	80MAX	EPA 551.1				LHW_DBP
UV254	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE	FREQUENCY
	ALPINE CREEK - RAW	AA04496	6/2/23	0.126	Abs/Tran		SM 5910B				LHW_MISC
	ALPINE CREEK - RAW	AA04687	6/7/23	0.073	Abs/Tran		SM 5910B				LHW_MISC
	ALPINE CREEK - RAW	AA04712	6/13/23	0.084	Abs/Tran		SM 5910B				LHW_MISC
	ALPINE CREEK - RAW	AA04740	6/22/23	0.167	Abs/Tran		SM 5910B				LHW_MISC
	ALPINE CREEK - RAW	AA04764	6/27/23	0.077	Abs/Tran		SM 5910B				LHW_MISC
			HIGH 0.17	AVG 0.11	LOW 0.07						
	TREATMENT PLANT - TREATED	AA04497	6/2/23	0.009	Abs/Tran		SM 5910B				LHW_MISC
	TREATMENT PLANT - TREATED	AA04688	6/7/23	0.036	Abs/Tran		SM 5910B				LHW_MISC
	TREATMENT PLANT - TREATED	AA04713	6/13/23	0.059	Abs/Tran		SM 5910B				LHW_MISC
	TREATMENT PLANT - TREATED	AA04741	6/22/23	0.040	Abs/Tran		SM 5910B				LHW_MISC
	TREATMENT PLANT - TREATED	AA04765	6/27/23	0.042	Abs/Tran		SM 5910B				LHW_MISC
			HIGH 0.06	AVG 0.04	LOW 0.01						

State of California
 Water Resources Control Board
 Division of Drinking Water
 Coliform Reporting Form

Date of Report: 7/10/2023

System Name: La Honda Water System (CSA #7)

System Number: CA4100509

Laboratory: BEI Analytical Laboratory

Elap No: 3019

Signature of Lab Director: *Greg W. Brucell*

Report Period from: 6/1/2023 to 6/30/2023

Sampler: Keefe Brennan

Employed by: Bracewell Engineering, Inc.

Collection Date	Laboratory Number	Bottle Number	Site Name or Street Address	Sample Type	Total Coliform	E. Coli	Remarks
6/13/2023			Old Chlorination Station	1	A	A	SM 9223B-18
6/13/2023			Raw Water	4	55.4	6.3	SM 9223 B-18 (MPN)

1 = Routine P = Present
 2 = Repeat A = Absent
 3 = Replacement
 4 = Other

**Monthly Summary of Monitoring
For Surface Water Treatment Regulations**

System Name: La Honda Water System (CSA #7)

System Number: 4100509

Treatment Plant Name: La Honda Water System (CSA #7)

Month: June Year: 2023

Treated Water Turbidities Every Four Hours (NTU)*

Date	Peak Raw Water Turbidity	Peak Settled Water Turbidity	Midnight to 0400	0400 to 0800	0800 to Noon	Noon to 1600	1600 to 2000	2000 to Midnight	Average Treated Water	Minimum Ct. Ratio
1										
2										
3										
4										
5										
6	1.05					0.05	0.04		0.04	3.0
7	0.95					0.05	0.04	0.04	0.05	3.7
8	1.19		0.07	0.04	0.04	0.09	0.05	0.04	0.05	3.4
9	1.31		0.04	0.04	0.04	0.05	0.05	0.04	0.04	4.4
10										
11	0.85				0.05	0.05	0.05	0.04	0.05	3.7
12	1.03		0.06	0.04	0.04	0.06	0.04	0.04	0.05	4.1
13	0.89		0.07	0.05	0.04	0.05	0.05	0.04	0.05	4.0
14	0.87		0.05	0.04	0.05	0.06	0.05	0.05	0.05	4.0
15										
16										
17										
18										
19										
20										
21										
22										
23	0.91						0.05	0.04	0.05	2.9
24	1.02		0.04	0.05	0.04	0.04	0.05	0.04	0.04	3.9
25	0.93		0.04	0.05	0.05	0.04	0.05	0.05	0.05	3.5
26	0.79		0.04		0.05	0.05	0.04	0.07	0.05	3.5
27	0.79		0.05	0.04	0.05	0.05	0.04	0.05	0.05	4.0
28	0.77		0.05	0.05		0.05	0.05	0.04	0.05	3.6
29	0.70		0.05	0.05	0.04				0.05	3.3
30										
31										
Ave.	0.94								0.05	2.9

*If a continuous monitoring turbidimeter is used, determine discrete turbidity value for the same times during each 24-hour period

Total No. of Samples: 72 No. of Readings ≤ 0.3 NTU: 72

% Readings ≤ 0.3 NTU = [(No. Readings ≤ 0.3 NTU) / (Total No. Samples)] x 100 = 100%

Meets Standard (i.e. more than 95% of readings are ≤ 0.3 NTU) (Y/N)? Y

Percent reduction during the month = [(Average Raw NTU - Average Effluent NTU) / (Average Raw NTU)] x 100 = 95%

Meets Standard (i.e. reduction is greater than 80%) (Y/N)? Y

95th Percentile Value of all turbidity readings (95% of all turbidity readings are less than this value) 0.062

Incidents of turbidity greater than 1.0 NTU

Date of Incident				
Value				
Duration				

Total Number of incidents where turbidity is > 1.0 NTU: 0
 Total Number of incidents where turbidity is > 5.0 NTU: 0
 Meets Standards (i.e. NTU is not > 1.0 for more than eight consecutive hours) (Y/N)? Y

After placing a filter back into service after any interruption (e.g. backwashing), did the filter effluent comply with the following criteria:

a. < 2.0 NTU after all events (Y/N)? Y
 b. < 1.0 NTU after 90% of events (Y/N)? Y
 c. < 0.5 NTU after 4 hours (Y/N)? Y

Indicate the date that the turbidimeters that are used for regulatory monitoring purposes were calibrated

Date	Which Turbidimeter	Standard used (primary/secondary)	Date	Which Turbidimeter	Standard Used (primary/secondary)
1/28/2022	Hach, raw wtr	0/20 Formazin	1/28/2022	Hach, treated	0/20 Formazin
4/28/2022	Hach, raw wtr	0/20 Formazin	4/28/2022	Hach, treated	0/20 Formazin
7/22/2022	Hach, raw wtr	0/20 Formazin	7/22/2022	Hach, treated	0/20 Formazin
10/26/2022	Hach, raw wtr	0/20 Formazin	10/26/2022	Hach, treated	0/20 Formazin
1/27/2023	Hach, raw wtr	0/20 Formazin	1/27/2023	Hach, treated	0/20 Formazin
6/2/2023	Hach, raw wtr	0/20 Formazin	6/2/2023	Hach, treated	0/20 Formazin

Disinfection Process Data

Disinfectant residual type: free chlorine: X combined chlorine: _____ other (specify) _____

Incidents of chlorine residuals less than 0.2 ppm at the plant effluent:

Date of Incident			
Duration			
Date Dept. Notified			

Total number of incidents where residual is < 0.2 ppm: 0
 Meets standard (i.e. not less than 0.2 ppm for more than four hours) (Y/N)? Y

No. of distribution system residual samples collected:	1
No of distribution system samples for HPC only:	
Total No. residual and/or HPC samples collected:	1
No. of samples with no detectable residual and HPC is not measured:	0
No. of samples with no residual and HPC > 500 CFU/ml:	
No. of samples for HPC only and HPC > 500 CFU/ml:	
Total No. Samples with no residual and/or HPC > 500 CFU/ml:	0

Compute V where $V = [1 - (\text{Total number of samples with no residual and/or HPC} > 500) / (\text{Total number of residual and/or HPC samples collected})] \times 100 =$ 100%

Meets Standard (i.e V > 95%) (Y/N) Y

**Quarterly Report for Disinfectant Residuals Compliance
For Systems Using Chlorine or Chloramines**

System Name: La Honda Water System (CSA #7) System No.: 4100509

Calendar Year: 2023 Quarter: 2

1st Quarter			
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)	
7/12/2010 Previous Year	April	1.10	
	May	1.16	
	June	1.09	
	July	1.48	
	August	1.63	
	September	1.70	
	October	1.29	
	November	1.32	
	December	1.06	
	Current Year	January	8
		February	5
		March	17
Running Annual Average (RAA):		1.10	
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		Yes	

2nd Quarter			
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)	
Previous Year	July	1.48	
	August	1.63	
	September	1.70	
	October	1.29	
	November	1.32	
	December	1.06	
	Current Year	January	0.42
		February	0.56
		March	0.44
		April	7
		May	5
		June	6
Running Annual Average (RAA):		1.03	
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		Yes	

3rd Quarter			
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)	
Previous Yr	October	1.29	
	November	1.32	
	December	1.06	
Current Year	January	0.42	
	February	0.56	
	March	0.44	
	April	0.86	
	May	0.83	
	June	0.81	
	July		
	August		
	September		
	Running Annual Average (RAA):		
	Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		

4th Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Current Year	January	0.42
	February	0.56
	March	0.44
	April	0.86
	May	0.83
	June	0.81
	July	
	August	
	September	
	October	
	November	
	December	
Running Annual Average (RAA):		
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		

Comments:

Signature: *Greg W. Baccant*

Date: 7/10/2023


Quarterly TTHM Report for Disinfection Byproducts Compliance (in µg/L or ppb)

System Name: La Honda Water System (CSA #7) System No.: 4100509 Year: 2022 Quarter: 2

Year:	2019				2020				2021				2022				2023			
Quarter:	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Sample Date (month/date):	3/5	6/19	9/11	12/17	3/10	6/9	9/8	12/1	3/1	6/14	9/8	12/7	3/1	6/14	9/13	12/13	3/28	6/13		
Site 1	79.5	62.5	115.2	104.6	61.2	40.0	39.0	67.0	38.0	71.0	53.0	75.1	31.0	65.0	80.0	102.0	44.0	40.0		
Quarterly Average	79.5	62.5	115.2	104.6	61.2	40.0	39.0	67.0	38.0	71.0	53.0	75.1	31.0	65.0	80.0	102.0	44.0	40.0		
Running Annual Average	77.7	79.8	90.2	90.5	85.9	80.3	61.2	51.8	46.0	53.8	57.3	59.3	57.5	56.0	62.8	69.5	72.8	66.5		
Meets Standard (80 ug/L)?*	Yes	Yes	No	No	No	No	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes		
Number of Samples Taken	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		

Identify the sample locations in the table below.

Site	Sample Location
1	Old Chlorination Station
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	



Signature *Logan W. Bassett* Date 7/10/2023

*If, during the first year of monitoring, any individual quarter's average will cause the running annual average of that system to exceed the standard, then the system is out of compliance at the end of that quarter.

Quarterly HAA5 Report for Disinfection Byproducts Compliance (in µg/L or ppb)

System Name: La Honda Water System System No.: 4100509 Year: 2022 Quarter: 2

Year:	2019				2020				2021				2022				2023			
Quarter:	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Sample Date (month/date):	3/5	6/19	9/11	12/17	3/10	6/9	9/8	12/1	3/1	6/14	9/8	12/7	3/1	6/14	9/13	12/13	3/28	6/13		
Site 1	46.0	44.3	64.0	83.5	101.6	69.0	29.0	32.0	25.0	55.0	19.0	40.0	22.0	35.0	43.0	87.0	19.0	32.0		
Site 1 Sample																				
Site 3																				
Site 4																				
Site 5																				
Site 6																				
Site 7																				
Site 8																				
Site 9																				
Site 10																				
Site 11																				
Site 12																				
Quarterly Average	46.0	44.3	64.0	83.5	101.6	69.0	29.0	32.0	25.0	55.0	19.0	40.0	22.0	35.0	43.0	87.0	19.0	32.0		
Running Annual Average	41.5	42.1	53.0	59.5	73.4	79.5	70.8	57.9	38.8	35.3	32.8	34.8	34.0	29.0	35.0	46.8	46.0	45.3		
Meets Standard (60 ug/L)?*	Yes	Yes	Yes	Yes	No	No	No	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes		
Number of Samples Taken	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		

Identify the sample locations in the table below.

Site	Sample Location
1	Old Chlorination Station
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	

Greg W. Beaman

Signature _____ Date 7/10/2023

*If, during the first year of monitoring, any individual quarter's average will cause the running annual average of that system to exceed the standard, then the system is out of compliance at the end of that quarter.