



BRACEWELL ENGINEERING, INC.

155 MAST STREET, UNIT 114, MORGAN HILL, CA 95037

(669) 258-5820 FAX (408) 498-7045

www.bracewellengineering.com

January 10, 2025

District Engineer
State Water Resources Control Board-Division of Drinking Water
850 Marina Bay Parkway, Building P, 2nd Floor
Richmond, CA 94804

Re: December 2024 Monthly Report to the Office of Drinking Water
La Honda Water System (County Service Area No. 7), No. CA4100509

Dear District Engineer:

Attached are the following:

1. Monitoring Report
 2. Lab Results
 3. Coliform Reporting Form
 4. Surface Water Reports
 5. Quarterly Report for Disinfectant Residuals Compliance
 6. Quarterly TTHM & HAA5 Reports for Disinfection Byproducts Compliance
- The data logger at the Storage Tank was removed and we are waiting on the findings.
 - The monthly distribution system treated water bacteriological sample showed an absence of total coliforms and E. coli.
 - Chlorine residuals were maintained as required.
 - The minimum Disinfection CT ratio was 1.9 for a DDW required 1- log removal for Giardia.
 - The quarterly disinfection byproducts monitoring was completed and the TTHM running annual average of 61.0 ug/L was in compliance with its MCL of 80 ug/L and the HAA5 running annual average of 41.8 ug/L was in compliance with its MCL of 60 ug/L.

Please do not hesitate to contact me if you have any questions.

Respectfully submitted,
BRACEWELL ENGINEERING, INC.

Alan Bracewell
Staff Engineer

Lhw Log Sheets

Location			Plant On	Raw Water	Raw Water	Treated Water	Backwash	Inlet	Inlet	Inlet
Parameter			SW Plant	Tank	Flow	Average Flow	Flow	pH	Max Turbidity	Turbidity
frequency			daily	daily	calculation	calculation	calculation	weekly	daily	weekly
Units			Y/N	ft	gal/d	gal/d	gal/d	units	ntu	ntu
Type				level	flow		flow		Analyzer	Grab
High Limit										
Low Limit										
Date	Initials	Time								
12/1/2024			N		12,165	-	1,243			
12/2/2024	Jo/Kb	1300	Y	13.96	12,165	18,950	1,243	7.4	1.44	1.49
12/3/2024			Y		10,715	33,450	729			
12/4/2024			N		10,715	-	729			
12/5/2024			N		10,715	-	729			
12/6/2024			N		10,715	-	729			
12/7/2024			N		10,715	-	729			
12/8/2024			N		10,715	-	729			
12/9/2024	Jo	1200	Y	13.76	10,715	33,450	729	8.54	1.19	1.27
12/10/2024			Y		8,382	27,467	845			
12/11/2024			Y		8,382	27,467	845			
12/12/2024			N		8,382	-	845			
12/13/2024			N		8,382	-	845			
12/14/2024			N		8,382	-	845			
12/15/2024			N		8,382	-	845			
12/16/2024			N		8,382	-	845			
12/17/2024			N		8,382	-	845			
12/18/2024			N		8,382	-	845			
12/19/2024			N		8,382	-	845			
12/20/2024	KB	1300	Y	14.4	8,382	27,467	845	8.49	2.51	3.20
12/21/2024			Y		54,348	49,333	6,700			
12/22/2024			Y		54,348	49,333	6,700			
12/23/2024	KB	930	Y	14.43	54,348	49,333	6,700	8.49	1.16	1.54
12/24/2024			Y		-	39,300	580			
12/25/2024			N		-	-	580			
12/26/2024			N		-	-	580			
12/27/2024			N		-	-	580			
12/28/2024			N		-	-	580			
12/29/2024			N		-	-	580			
12/30/2024			N		-	-	580			
12/31/2024			N		-	-	580			
Min				13.76	-	-	580	7.4	1.164	1.27
Max				14.43	54,348	49,333	6,700	8.54	2.51	3.2
Average				14.14	11,438	11,469	1,343	8.23	1.576	1.88
Total					354,585	355,550	41,626			

LHW

December

La Honda Water System (W4100509)

CALIBRATION TURBIDITY	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA09430	12/19/24	Pass						
	Treated Water	AA09431	12/19/24	Pass						
CHLORINE RESIDUAL	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	14251 Pescadero Creek	AA11256	12/10/24	1.25	mg/L		SM 4500-CI G	0.02	0.02	Routine
COLIFORM MPN	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA11255	12/10/24	74.3	MPN/100mL		SM9223B-18 (MPN)	1.0	1.0	Other
COLIFORM PA	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	14251 Pescadero Creek	AA11256	12/10/24	A	P/A		SM9223B-18			Routine
E COLI MPN	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA11255	12/10/24	9.7	MPN/100mL		SM9223B-18 (MPN)	1.0	1.0	Other
E COLI PA	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	14251 Pescadero Creek	AA11256	12/10/24	A	P/A		SM9223B-18			Routine
HALO ACETI	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Old Chlorination Station- Sam McDonald Park	AA11257	12/10/24	47	µg/L	60	EPA 552.2	2	1	
TTHM	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Old Chlorination Station- Sam McDonald Park	AA11257	12/10/24	51	µg/L	80	EPA 551.1			
UV254 PERF	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA11318	12/6/24	0.125	1/cm		SM 5910B			
	Alpine Creek - Raw Water	AA11342	12/10/24	0.092	1/cm		SM 5910B			
			HIGH 0.13	AVG 0.11	LOW 0.09					
	Treated Water	AA11319	12/6/24	0.080	1/cm		SM 5910B			
	Treated Water	AA11343	12/10/24	0.065	1/cm		SM 5910B			
			HIGH 0.08	AVG 0.07	LOW 0.07					

Monthly Summary of Monitoring
For Surface Water Treatment Regulations

System Name: La Honda Water System (CSA #7)

System Number: CA4100509

Treatment Plant Name: La Honda Water System (CSA #7)

Month: December Year: 2024

Treated Water Turbidities Every Four Hours (NTU)*

Date	Peak Raw Water Turbidity	Peak Settled Water Turbidity	Midnight to 0400	0400 to 0800	0800 to Noon	Noon to 1600	1600 to 2000	2000 to Midnight	Average Treated Water	Minimum Ct. Ratio
1										
2	3.94					0.03	0.04	0.03	0.04	2.8
3	0.74		0.05	0.04	0.03	0.05	0.04		0.04	3.3
4										
5										
6										
7										
8										
9	1.95					0.05	0.04	0.03	0.04	2.6
10	0.64		0.03	0.04	0.04	0.03	0.05	0.04	0.04	2.4
11	0.46		0.03						0.03	1.9
12										
13										
14										
15										
16										
17										
18										
19										
20	3.38					0.04	0.05	0.04	0.05	3.4
21	1.64		0.04	0.03	0.04	0.05	0.05	0.04	0.04	3.0
22	1.45		0.04	0.05	0.06	0.04	0.13	0.05	0.06	2.7
23	1.58		0.04	0.06	0.04	0.04	0.05	0.04	0.05	3.8
24	11.45		0.06	0.05					0.06	3.5
25										
26										
27										
28										
29										
30										
31										
Ave.	2.72								0.04	1.9

*If a continuous monitoring turbidimeter is used, determine discrete turbidity value for the same times during each 24-hour period

Total No. of Samples: 41 No. of Readings ≤ 0.3 NTU: 41

% Readings ≤ 0.3 NTU = [(No. Readings ≤ 0.3 NTU) / (Total No. Samples)] x 100 = 100%

Meets Standard (i.e. more than 95% of readings are ≤ 0.3 NTU) (Y/N)? Y

Percent reduction during the month = [(Average Raw NTU - Average Effluent NTU) / (Average Raw NTU)] x 100 = 98%

Meets Standard (i.e. reduction is greater than 80%) (Y/N)? Y

95th Percentile Value of all turbidity readings (95% of all turbidity readings are less than this value) 0.059

Incidents of turbidity greater than 1.0 NTU

Date of Incident				
Value				
Duration				

Total Number of incidents where turbidity is > 1.0 NTU: _____ 0
 Total Number of incidents where turbidity is > 5.0 NTU: _____ 0
 Meets Standards (i.e. NTU is not > 1.0 for more than eight consecutive hours) (Y/N)? _____ Y

After placing a filter back into service after any interruption (e.g. backwashing), did the filter effluent comply with the following criteria:

a. < 2.0 NTU after all events (Y/N)? _____ Y
 b. < 1.0 NTU after 90% of events (Y/N)? _____ Y
 c. < 0.5 NTU after 4 hours (Y/N)? _____ Y

Indicate the date that the turbidimeters that are used for regulatory monitoring purposes were calibrated

Date	Which Turbidimeter	Standard used (primary/secondary)	Date	Which Turbidimeter	Standard Used (primary/secondary)
1/27/2023	Hach, raw wtr	0/20 Formazin	1/27/2023	Hach, treated	0/20 Formazin
6/2/2023	Hach, raw wtr	0/20 Formazin	6/2/2023	Hach, treated	0/20 Formazin
9/27/2023	Hach, raw wtr	0/20 Formazin	9/27/2023	Hach, treated	0/20 Formazin
12/28/2023	Hach, raw wtr	0/20 Formazin	12/28/2023	Hach, treated	0/20 Formazin
3/28/2024	Hach, raw wtr	0/20 Formazin	3/28/2024	Hach, treated	0/20 Formazin
6/25/2024	Hach, raw wtr	0/20 Formazin	6/25/2024	Hach, treated	0/20 Formazin
6/25/2024	Hach, raw wtr	0/20 Formazin	6/25/2024	Hach, treated	0/20 Formazin
9/19/2024	Hach, raw wtr	0/20 Formazin	9/19/2024	Hach, treated	0/20 Formazin
12/19/2024	Hach, raw wtr	0/20 Formazin	12/19/2024	Hach, treated	0/20 Formazin

Disinfection Process Data

Disinfectant residual type: free chlorine: _____ X _____ combined chlorine: _____ other (specify) _____

Incidents of chlorine residuals less than 0.2 ppm at the plant effluent:

Date of Incident			
Duration			
Date Dept. Notified			

Total number of incidents where residual is < 0.2 ppm: _____ 0
 Meets standard (i.e. not less than 0.2 ppm for more than four hours) (Y/N)? _____ Y

No. of distribution system residual samples collected:	1
No of distribution system samples for HPC only:	
Total No. residual and/or HPC samples collected:	1
No. of samples with no detectable residual and HPC is not measured:	0
No. of samples with no residual and HPC > 500 CFU/ml:	
No. of samples for HPC only and HPC > 500 CFU/ml:	
Total No. Samples with no residual and/or HPC > 500 CFU/ml:	0

Compute V where $V = [1 - (\text{Total number of samples with no residual and/or HPC} > 500) / (\text{Total number of residual and/or HPC samples collected})] \times 100 =$ _____ 100%

Meets Standard (i.e V > 95%) (Y/N) _____ Y

Summary of Water Quality Complaints

General Complaints

Type of Complaint	Number	Corrective Actions Taken
Taste/Odor	0	
Color	0	
Turbidity	0	
Suspended Solids	0	
Other (describe)	0	

Reports of Gastrointestinal Illness (Attach additional sheets if necessary):

Person Reporting	Date	Corrective Actions Taken

Attach explanation of any failure of the performance standards or operating criteria and corrective action taken or planned

Signature:

Gregory W. Baccantelli

Date:

1/10/2025

**Quarterly Report for Disinfectant Residuals Compliance
For Systems Using Chlorine or Chloramines**

System Name: La Honda Water System (CSA #7) System No.: CA4100509

Calendar Year: 2024 Quarter: 4

1st Quarter			
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)	
7/12/2010	April	1.10	
	May	1.16	
	June	1.09	
	July	1.48	
	August	1.63	
	September	1.70	
	October	1.29	
	November	1.32	
	December	1.06	
	Current Year	January	6
		February	14
		March	5
Running Annual Average (RAA):		1.16	
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		Yes	

2nd Quarter			
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)	
Previous Year	July	1.48	
	August	1.63	
	September	1.70	
	October	1.29	
	November	1.32	
	December	1.06	
	Current Year	January	0.36
		February	0.70
		March	0.99
		April	6
		May	5
		June	7
Running Annual Average (RAA):		1.13	
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		Yes	

3rd Quarter			
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)	
Previous Yr	October	1.29	
	November	1.32	
	December	1.06	
Current Year	January	0.36	
	February	0.70	
	March	0.99	
	April	1.36	
	May	0.93	
	June	0.78	
	July	5	
	August	5	
	September	3	
	Running Annual Average (RAA):		0.98
	Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		Yes

4th Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Current Year	January	0.36
	February	0.70
	March	0.99
	April	1.36
	May	0.93
	June	0.78
	July	0.80
	August	0.98
	September	1.17
	October	4
	November	5
	December	5
Running Annual Average (RAA):		0.89
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		Yes

Comments:

Signature: *Gregory A. Baccell*

Date: 1/10/2025


Quarterly TTHM Report for Disinfection Byproducts Compliance (in µg/L or ppb)

System Name: La Honda Water System (CSA #7) System No.: CA4100509 Year: 2024 Quarter: 4

Year:	2020				2021				2022				2023				2024			
Quarter:	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Sample Date (month/date):	3/10	6/9	9/8	12/1	3/1	6/14	9/8	12/7	3/1	6/14	9/13	12/13	3/28	6/13	9/20	12/13	3/19	6/24	9/18	12/10
Site 1	61.2	40.0	39.0	67.0	38.0	71.0	53.0	75.1	31.0	65.0	80.0	102.0	44.0	40.0	68.0	56.0	42.0	92.0	59.0	51.0
Quarterly Average	61.2	40.0	39.0	67.0	38.0	71.0	53.0	75.1	31.0	65.0	80.0	102.0	44.0	40.0	68.0	56.0	42.0	92.0	59.0	51.0
Running Annual Average	77.7	79.8	90.2	51.8	46.0	53.8	57.3	59.3	57.5	56.0	62.8	69.5	72.8	66.5	63.5	52.0	51.5	64.5	62.3	61.0
Meets Standard (80 ug/L)?*	Yes	Yes	No	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Number of Samples Taken	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

Identify the sample locations in the table below.

Site	Sample Location
1	Old Chlorination Station
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	



Signature *Logan W. Bassett* Date 1/10/2025

*If, during the first year of monitoring, any individual quarter's average will cause the running annual average of that system to exceed the standard, then the system is out of compliance at the end of that quarter.

Quarterly HAA5 Report for Disinfection Byproducts Compliance (in µg/L or ppb)

System Name: La Honda Water System System No.: CA4100509 Year: 2024 Quarter: 4

Year:	2020				2021				2022				2023				2024			
Quarter:	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Sample Date (month/date):	3/10	6/9	9/8	12/1	3/1	6/14	9/8	12/7	3/1	6/14	9/13	12/13	3/28	6/13	9/20	12/13	3/19	6/24	9/18	12/10
Site 1	101.6	69.0	29.0	32.0	25.0	55.0	19.0	40.0	22.0	35.0	43.0	87.0	19.0	32.0	42.0	34.0	31.0	28.0	61.0	47.0
Site 1 Sample																				
Site 3																				
Site 4																				
Site 5																				
Site 6																				
Site 7																				
Site 8																				
Site 9																				
Site 10																				
Site 11																				
Site 12																				
Quarterly Average	101.6	69.0	29.0	32.0	25.0	55.0	19.0	40.0	22.0	35.0	43.0	87.0	19.0	32.0	42.0	34.0	31.0	28.0	61.0	47.0
Running Annual Average	41.5	42.1	53.0	57.9	38.8	35.3	32.8	34.8	34.0	29.0	35.0	46.8	46.0	45.3	45.0	31.8	34.8	33.8	38.5	41.8
Meets Standard (60 ug/L)?*	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Number of Samples Taken	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

Identify the sample locations in the table below.

Site	Sample Location
1	Old Chlorination Station
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	

Steph W. Beccard

Signature _____ Date 1/10/2025

*If, during the first year of monitoring, any individual quarter's average will cause the running annual average of that system to exceed the standard, then the system is out of compliance at the end of that quarter.

State of California
Water Resources Control Board
Division of Drinking Water
Coliform Reporting Form

Date of Report: January 03, 2025

Laboratory: BEI Analytical Laboratory (ELAP 3019)

Report Period: December, 2024

System Name: **La Honda Water System**

System Number: **CA4100509**

Collection Date	Site Name	Analyte	Sample Type	Result	Remarks	Sampler
12/10/2024	Alpine Creek - Raw Water	Coliform	Other	74.3	SM9223B-18 (MPN)	Keefe Brennan
12/10/2024	Alpine Creek - Raw Water	E. Coli	Other	9.7	SM9223B-18 (MPN)	Keefe Brennan
12/10/2024	14251 Pescadero Creek	COLIFORM	Routine	A	SM9223B-18	Keefe Brennan
12/10/2024	14251 Pescadero Creek	E. COLI	Routine	A	SM9223B-18	Keefe Brennan

1 = Routine
2 = Repeat
3 = Replacement
4 = Other
P = Present
A = Absent