



BRACEWELL ENGINEERING, INC.

155 MAST STREET, UNIT 114, MORGAN HILL, CA 95037

(669) 258-5820 FAX (408) 498-7045

www.bracewellengineering.com

October 10, 2025

District Engineer

State Water Resources Control Board-Division of Drinking Water

850 Marina Bay Parkway, Building P, 2nd Floor

Richmond, CA 94804

Re: September 2025 Monthly Report to the Office of Drinking Water
La Honda Water System (County Service Area No. 7), No. CA4100509

Dear District Engineer:

Attached are the following:

1. Monitoring Report
 2. Lab Results
 3. Coliform Reporting Form
 4. Surface Water Reports
 5. Quarterly Report for Disinfectant Residuals Compliance
 6. Quarterly TTHM & HAA5 Reports for Disinfection Byproducts Compliance
- Due to a leak at 8050 La Honda Rd., a shut-off notice was distributed. Once the leak was repaired, a boil water notice was issued and remained in effect until follow-up bacteriological samples were collected and confirmed absent of total coliforms and E. coli.
 - The quarterly disinfection byproducts monitoring was completed and the TTHM running annual average of 60.3 ug/L was in compliance with its MCL of 80 ug/L and the HAA5 running annual average of 49.3 ug/L was in compliance with its MCL of 60 ug/L. We continue to run the Storage Tank aeration pump in hand as we wait for a solution to the automatic operation of the device.
 - The monthly distribution system treated water bacteriological sample showed an absence of total coliforms and E. coli.
 - Chlorine residuals were maintained as required.
 - The minimum Disinfection CT ratio was 5.2 for a DDW required 1- log removal for Giardia.

Please do not hesitate to contact me if you have any questions.

Respectfully submitted,
BRACEWELL ENGINEERING, INC.

Alan Bracewell
Staff Engineer

Lhw Log Sheets

Location			Plant On	Raw Water	Raw Water	Treated Water	Backwash	Inlet	Inlet	Inlet	Inlet	Creek	Air	Air
Parameter			SW Plant	Tank	Flow	Average Flow	Flow	pH	Max Turbidity	Turbidity	Temp.	Water Level	Temp	Percip
frequency			daily	daily	calculation	calculation	calculation	weekly	daily	weekly	weekly	monthly	daily	daily
Units			Y/N	ft	gal/d	gal/d	gal/d	units	ntu	ntu	C	inches	C	%
Type				level	flow		flow		Analyzer	Grab	Grab	grab		
High Limit														
Low Limit														
Date	Initials	Time												
9/1/2025			N		8,202	-	540							
9/2/2025			N		8,202	-	540							
9/3/2025	KB	900	N	14.51	8,202	-	540							
9/4/2025			N		2,549	-	40							
9/5/2025			N		2,549	-	40							
9/6/2025			N		2,549	-	40							
9/7/2025			N		2,549	-	40							
9/8/2025	KB	1615	Y	13.02	2,549	25,133	40		2.44				20.3	33%
9/9/2025			Y		21,684	25,133	2,075							
9/10/2025			Y		21,684	25,133	2,075							
9/11/2025			N		21,684	-	2,075							
9/12/2025	KB	1530	Y	13	21,684	25,133	2,075	8.5	0.42	0.50	17.1		16.4	37%
9/13/2025			Y		26,809	34,950	2,767							
9/14/2025			N		26,809	-	2,767							
9/15/2025	KB	1445	Y	14.58	26,809	34,950	2,767	8.5	0.41	0.68	17.9		23.8	32%
9/16/2025			Y		1	53,900	4,200							
9/17/2025	KB	1445	Y	14	1	53,900	4,200		0.48				22.4	33%
9/18/2025			Y		65,330	55,050	5,600							
9/19/2025	KB	1400	Y	13.09	65,330	55,050	5,600		0.51				19.7	34%
9/20/2025			Y		8,014	37,800	773							
9/21/2025			N		8,014	-	773							
9/22/2025			N		8,014	-	773							
9/23/2025			N		8,014	-	773							
9/24/2025			N		8,014	-	773							
9/25/2025			N		8,014	-	773							
9/26/2025			N		8,014	-	773							
9/27/2025			N		8,014	-	773							
9/28/2025			N		8,014	-	773							
9/29/2025			N		8,014	-	773							
9/30/2025	KB	945	Y	14.92	8,014	37,800	773	8.5	0.76	1.01	16.8	13"	16.6	43%
Min				13	1	-	40	8.5	0.411	0.5	16.8	0	16.4	32%
Max				14.92	65,330	55,050	5,600	8.5	2.442	1.01	17.9	0	23.8	43%
Average				13.87	14,111	15,464	1,551	8.5	0.836	0.73	17.3		19.9	35%
Total					423,324	463,933	46,520							

Lhw Log Sheets

[illegible]

Lhw Log Sheets

Location	TW Storage Tank	TW Storage Tank	TW Storage Tank	Aeration System	Aeration System	Aeration System	Routine Sample Site	
Parameter	Temp	pH	cl2 residual	Run in Hand	Pump Recirc Discharge	Recirc Pump Discharge	Cl2 Residual	
frequency	weekly	weekly	weekly	as needed	weekly	weekly	as needed	
Units	C	Units	ppm	Yes/No	min	min	mg/L	
Type							grab	
High Limit	17	8.5	2					
Low Limit	6.5	7.5	0.3					
Date								
9/1/2025				N			0.34	
9/2/2025				N				
9/3/2025				N				
9/4/2025				N				
9/5/2025				N				
9/6/2025				N				
9/7/2025				N				
9/8/2025				Y				
9/9/2025				Y			1.28	
9/10/2025				Y				
9/11/2025				Y				
9/12/2025	17.2	8.5	0.62	Y				
9/13/2025				Y				
9/14/2025				Y				
9/15/2025				Y				
9/16/2025				Y			1.13	
9/17/2025				Y				
9/18/2025				Y				
9/19/2025				Y				
9/20/2025				Y				
9/21/2025				Y				
9/22/2025				Y				
9/23/2025				N			0.44	
9/24/2025				N				
9/25/2025				N				
9/26/2025				N				
9/27/2025				N				
9/28/2025				N				
9/29/2025				N				
9/30/2025				Y				
Min	17.2	8.5	0.62		0	0	0.34	
Max	17.2	8.5	0.62		0	0	1.28	
Average	17.2	8.5	0.62				0.8	
Total								

CALIBRATION TURBIDITY	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA19105	9/29/25	Pass						
	Treated Water	AA19106	9/29/25	Pass						
CHLORINE RESIDUAL	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	11 Pope Rd	AA19830	9/9/25	1.28	mg/L		SM 4500-CI G	0.02	0.02	Other
	11 Pope Rd	AA19834	9/16/25	1.08	mg/L		SM 4500-CI G	0.02	0.02	Other
		AA19868	9/17/25	2.14	mg/L		SM 4500-CI G	0.02	0.02	Other
				HIGH 2.14	AVG 1.50	LOW 1.08				
	25 Memory Ln - Station 12	AA19832	9/9/25	0.32	mg/L		SM 4500-CI G	0.02	0.02	Other
	25 Memory Ln - Station 12	AA19836	9/16/25	0.36	mg/L		SM 4500-CI G	0.02	0.02	Other
		AA19866	9/17/25	0.71	mg/L		SM 4500-CI G	0.02	0.02	Other
				HIGH 0.71	AVG 0.46	LOW 0.32				
	400 Ranch Rd. La Honda - Glenwood Boy's Ranch	AA19702	9/16/25	1.03	mg/L		SM 4500-CI G	0.02	0.02	Routine
	8050 La Hona Road	AA19829	9/9/25	1.53	mg/L		SM 4500-CI G	0.02	0.02	Other
	8050 La Hona Road	AA19833	9/16/25	1.13	mg/L		SM 4500-CI G	0.02	0.02	Other
		AA19869	9/17/25	1.74	mg/L		SM 4500-CI G	0.02	0.02	Other
				HIGH 1.74	AVG 1.47	LOW 1.13				
	8181 La Hona Road	AA19831	9/9/25	1.07	mg/L		SM 4500-CI G	0.02	0.02	Other
	8181 La Hona Road	AA19835	9/16/25	0.81	mg/L		SM 4500-CI G	0.02	0.02	Other
		AA19867	9/17/25	1.90	mg/L		SM 4500-CI G	0.02	0.02	Other
				HIGH 1.90	AVG 1.26	LOW 0.81				
COLIFORM MPN	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA19701	9/16/25	141.4	MPN/100mL		SM9223B-18 (MPN)	1.0	1.0	Other
COLIFORM PA	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	11 Pope Rd	AA19830	9/9/25	A	P/A		SM9223B-18			Other
	11 Pope Rd	AA19868	9/17/25	A	P/A		SM9223B-18			Other
		AA19834	9/16/25	A	P/A		SM9223B-18			Other
				HIGH	AVG	LOW				
	25 Memory Ln - Station 12	AA19832	9/9/25	A	P/A		SM9223B-18			Other
	25 Memory Ln - Station 12	AA19836	9/16/25	A	P/A		SM9223B-18			Other
		AA19866	9/17/25	A	P/A		SM9223B-18			Other
				HIGH	AVG	LOW				
	400 Ranch Rd. La Honda - Glenwood Boy's Ranch	AA19702	9/16/25	A	P/A		SM9223B-18			Routine
	8050 La Hona Road	AA19829	9/9/25	A	P/A		SM9223B-18			Other
	8050 La Hona Road	AA19833	9/16/25	A	P/A		SM9223B-18			Other
		AA19869	9/17/25	A	P/A		SM9223B-18			Other
				HIGH	AVG	LOW				
	8181 La Hona Road	AA19831	9/9/25	A	P/A		SM9223B-18			Other
	8181 La Hona Road	AA19835	9/16/25	A	P/A		SM9223B-18			Other
		AA19867	9/17/25	A	P/A		SM9223B-18			Other

September	La Honda Water System									
			HIGH	AVG	LOW					
E COLI MPN	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA19701	9/16/25	85.7	MPN/100mL		SM9223B-18 (MPN)	1.0	1.0	Other
E COLI PA	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	11 Pope Rd	AA19830	9/9/25	A	P/A		SM9223B-18			Other
	11 Pope Rd	AA19834	9/16/25	A	P/A		SM9223B-18			Other
		AA19868	9/17/25	A	P/A		SM9223B-18			Other
			HIGH	AVG	LOW					
	25 Memory Ln - Station 12	AA19832	9/9/25	A	P/A		SM9223B-18			Other
	25 Memory Ln - Station 12	AA19836	9/16/25	A	P/A		SM9223B-18			Other
		AA19866	9/17/25	A	P/A		SM9223B-18			Other
			HIGH	AVG	LOW					
	400 Ranch Rd. La Honda - Glenwood Boy's Ranch	AA19702	9/16/25	A	P/A		SM9223B-18			Routine
	8050 La Hona Road	AA19829	9/9/25	A	P/A		SM9223B-18			Other
	8050 La Hona Road	AA19833	9/16/25	A	P/A		SM9223B-18			Other
		AA19869	9/17/25	A	P/A		SM9223B-18			Other
			HIGH	AVG	LOW					
	8181 La Hona Road	AA19831	9/9/25	A	P/A		SM9223B-18			Other
	8181 La Hona Road	AA19835	9/16/25	A	P/A		SM9223B-18			Other
		AA19867	9/17/25	A	P/A		SM9223B-18			Other
			HIGH	AVG	LOW					
HALO ACETI	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Old Chlorination Station- Sam McDonald Park	AA19703	9/16/25	52	µg/L	60	EPA 552.2	2	1	
TTHM	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Old Chlorination Station- Sam McDonald Park	AA19703	9/16/25	58	µg/L	80	EPA 551.1			
UV254 PERF	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA19849	9/16/25	0.066	1/cm		SM 5910B			
	Treated Water	AA19850	9/16/25	0.087	1/cm		SM 5910B			

Monthly Summary of Monitoring For Surface Water Treatment Regulations

System Name: La Honda Water System (CSA #7)

System Number: CA4100509

Treatment Plant Name: La Honda Water System (CSA #7)

Month: September Year: 2025

Treated Water Turbidities Every Four Hours (NTU)*

Date	Peak Raw Water Turbidity	Peak Settled Water Turbidity	Midnight to 0400	0400 to 0800	0800 to Noon	Noon to 1600	1600 to 2000	2000 to Midnight	Average Treated Water	Minimum Ct. Ratio
1										
2										
3										
4										
5										
6										
7										
8	5.84					0.06	0.05	0.05	0.05	7.1
9	1.05		0.05	0.05	0.06	0.05	0.05	0.06	0.05	8.1
10	0.46					0.14			0.14	5.6
11										
12	3.69					0.05	0.05	0.05	0.05	8.0
13	0.87		0.05	0.05	0.05	0.06	0.05	0.05	0.05	7.7
14										
15	1.03						0.07	0.06	0.06	7.7
16	1.21		0.05	0.06	0.06	0.05		0.06	0.06	8.9
17	1.00		0.05	0.09	0.06	0.05	0.05	0.06	0.06	7.9
18	1.03		0.05	0.05	0.06	0.05	0.05	0.06	0.05	8.3
19	0.90		0.05	0.05	0.06	0.05	0.05	0.06	0.05	7.7
20	0.90		0.05	0.05	0.06	0.05	0.05	0.06	0.05	
21										
22										
23										
24										
25										
26										
27										
28										
29										
30	2.25					0.06	0.06	0.06	0.06	5.2
31										
Ave.	1.68								0.06	5.2

*If a continuous monitoring turbidimeter is used, determine discrete turbidity value for the same times during each 24-hour period

Total No. of Samples: 53 No. of Readings ≤ 0.3 NTU: 53

% Readings ≤ 0.3 NTU = [(No. Readings ≤ 0.3 NTU) / (Total No. Samples)] x 100 = 100%

Meets Standard (i.e. more than 95% of readings are ≤ 0.3 NTU) (Y/N)? Y

Percent reduction during the month = $\frac{[(\text{Average Raw NTU} - \text{Average Effluent NTU})]}{(\text{Average Raw NTU})} \times 100 =$ 97%

Meets Standard (i.e. reduction is greater than 80%) (Y/N)? Y

95th Percentile Value of all turbidity readings (95% of all turbidity readings are less than this value) 0.064

Incidents of turbidity greater than 1.0 NTU

Date of Incident				
Value				
Duration				

Total Number of incidents where turbidity is > 1.0 NTU: 0

Total Number of incidents where turbidity is > 5.0 NTU: 0

Meets Standards (i.e. NTU is not > 1.0 for more than eight consecutive hours) (Y/N)? Y

After placing a filter back into service after any interruption (e.g. backwashing), did the filter effluent comply with the following criteria:

a. < 2.0 NTU after all events (Y/N)? Y

b. < 1.0 NTU after 90% of events (Y/N)? Y

c. < 0.5 NTU after 4 hours (Y/N)? Y

Indicate the date that the turbidimeters that are used for regulatory monitoring purposes were calibrated

Date	Which Turbidimeter	Standard used (primary/secondary)	Date	Which Turbidimeter	Standard Used (primary/secondary)
3/28/2024	Hach, raw wtr	0/20 Formazin	3/28/2024	Hach, treated	0/20 Formazin
6/25/2024	Hach, raw wtr	0/20 Formazin	6/25/2024	Hach, treated	0/20 Formazin
6/25/2024	Hach, raw wtr	0/20 Formazin	6/25/2024	Hach, treated	0/20 Formazin
9/19/2024	Hach, raw wtr	0/20 Formazin	9/19/2024	Hach, treated	0/20 Formazin
12/19/2024	Hach, raw wtr	0/20 Formazin	12/19/2024	Hach, treated	0/20 Formazin
3/28/2025	Hach, raw wtr	0/20 Formazin	3/28/2025	Hach, treated	0/20 Formazin
6/27/2025	Hach, raw wtr	0/20 Formazin	6/27/2025	Hach, treated	0/20 Formazin
9/29/2025	Hach, raw wtr	0/20 Formazin	9/29/2025	Hach, treated	0/20 Formazin

Disinfection Process Data

Disinfectant residual type: free chlorine: X combined chlorine: other (specify)

Incidents of chlorine residuals less than 0.2 ppm at the plant effluent:

Date of Incident				
Duration				
Date Dept. Notified				

Total number of incidents where residual is < 0.2 ppm: 0

Meets standard (i.e. not less than 0.2 ppm for more than four hours) (Y/N)? Y

No. of distribution system residual samples collected:	1
No of distribution system samples for HPC only:	
Total No. residual and/or HPC samples collected:	1
No. of samples with no detectable residual and HPC is not measured:	0
No. of samples with no residual and HPC > 500 CFU/ml:	
No. of samples for HPC only and HPC > 500 CFU/ml:	
Total No. Samples with no residual and/or HPC > 500 CFU/ml:	0

Compute V where $V = [1 - (\text{Total number of samples with no residual and/or HPC} > 500) / (\text{Total number of residual and/or HPC samples collected})] \times 100 =$ 100%

Meets Standard (i.e V > 95%) (Y/N) Y

Summary of Water Quality Complaints

General Complaints

Type of Complaint	Number	Corrective Actions Taken
Taste/Odor	0	
Color	0	
Turbidity	0	
Suspended Solids	0	
Other (describe)	0	

Reports of Gastrointestinal Illness (Attach additional sheets if necessary):

Person Reporting	Date	Corrective Actions Taken

Attach explanation of any failure of the performance standards or operating criteria and corrective action taken or planned

Signature:

Gregory A. Brannen

Date:

10/10/2025

**Quarterly Report for Disinfectant Residuals Compliance
For Systems Using Chlorine or Chloramines**

System Name: La Honda Water System (CSA #7) System No.: CA4100509

Calendar Year: 2025 Quarter: 3

1st Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
7/12/2010 Previous Year	April	1.10
	May	1.16
	June	1.09
	July	1.48
	August	1.63
	September	1.70
	October	1.29
	November	1.32
	December	1.06
	January	1.22
Current Year	January	12
	February	11
	March	5
Running Annual Average (RAA):		1.22
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		Yes

2nd Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Previous Year	July	1.48
	August	1.63
	September	1.70
	October	1.29
	November	1.32
	December	1.06
	January	0.81
	February	0.81
	March	1.24
	April	0.58
Current Year	May	4
	June	5
Running Annual Average (RAA):		1.15
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		Yes

3rd Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Previous Yr	October	1.29
	November	1.32
	December	1.06
Current Year	January	0.81
	February	0.81
	March	1.24
	April	0.58
	May	0.87
	June	1.07
	July	7
	August	4
	September	17
	October	1.08
Running Annual Average (RAA):		1.04
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		Yes

4th Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Current Year	January	0.81
	February	0.81
	March	1.24
	April	0.58
	May	0.87
	June	1.07
	July	1.12
	August	1.27
	September	1.08
	October	
	November	
	December	
Running Annual Average (RAA):		
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		

Comments:

Signature: *Steph A. Baccantelli*

Date: 10/10/2025


Quarterly TTHM Report for Disinfection Byproducts Compliance (in µg/L or ppb)

System Name: La Honda Water System (CSA #7) System No.: CA4100509 Year: 2025 Quarter: 3

Year:	2021				2022				2023				2024				2025			
Quarter:	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Sample Date (month/date):	3/1	6/14	9/8	12/7	3/1	6/14	9/13	12/13	3/28	6/13	9/20	12/13	3/19	6/24	9/18	12/10	3/20	6/3	9/29	
Site 1	38.0	71.0	53.0	75.1	31.0	65.0	80.0	102.0	44.0	40.0	68.0	56.0	42.0	92.0	59.0	51.0	85.0	47.0	58.0	
Quarterly Average	38.0	71.0	53.0	75.1	31.0	65.0	80.0	102.0	44.0	40.0	68.0	56.0	42.0	92.0	59.0	51.0	85.0	47.0	58.0	
Running Annual Average	77.7	79.8	90.2	59.3	57.5	56.0	62.8	69.5	72.8	66.5	63.5	52.0	51.5	64.5	62.3	61.0	71.8	60.5	60.3	
Meets Standard (80 ug/L)?*	Yes	Yes	No	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
Number of Samples Taken	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	

Identify the sample locations in the table below.

Site	Sample Location
1	Old Chlorination Station
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	



Signature

10/10/2025

Date

*If, during the first year of monitoring, any individual quarter's average will cause the running annual average of that system to exceed the standard, then the system is out of compliance at the end of that quarter.

Quarterly HAA5 Report for Disinfection Byproducts Compliance (in µg/L or ppb)

System Name: La Honda Water System System No.: CA4100509 Year: 2025 Quarter: 3

Year:	2021				2022				2023				2024				2025			
Quarter:	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Sample Date (month/date):	3/1	6/14	9/8	12/7	3/1	6/14	9/13	12/13	3/28	6/13	9/20	12/13	3/19	6/24	9/18	12/10	3/20	6/3	9/29	
Site 1	25.0	55.0	19.0	40.0	22.0	35.0	43.0	87.0	19.0	32.0	42.0	34.0	31.0	88.0	61.0	47.0	59.0	39.0	52.0	
Site 1 Sample																				
Site 3																				
Site 4																				
Site 5																				
Site 6																				
Site 7																				
Site 8																				
Site 9																				
Site 10																				
Site 11																				
Site 12																				
Quarterly Average	25.0	55.0	19.0	40.0	22.0	35.0	43.0	87.0	19.0	32.0	42.0	34.0	31.0	88.0	61.0	47.0	59.0	39.0	52.0	
Running Annual Average	41.5	42.1	53.0	34.8	34.0	29.0	35.0	46.8	46.0	45.3	45.0	31.8	34.8	48.8	53.5	56.8	63.8	51.5	49.3	
Meets Standard (60 ug/L)?*	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	No	Yes	Yes	
Number of Samples Taken	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	

Identify the sample locations in the table below.

Site	Sample Location
1	Old Chlorination Station
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	

Steph W. Bueckert 10/10/2025
Signature Date

*If, during the first year of monitoring, any individual quarter's average will cause the running annual average of that system to exceed the standard, then the system is out of compliance at the end of that quarter.

State of California
Water Resources Control Board
Division of Drinking Water
Coliform Reporting Form

Date of Report: October 06, 2025

Laboratory: BEI Analytical Laboratory (ELAP 3019)

Report Period: September, 2025

System Name: **La Honda Water System**

System Number: **CA4100509**

Collection Date	Site Name	Analyte	Sample Type	Result	Remarks	Sampler
9/9/2025	8050 La Hona Road	COLIFORM	Other	A	SM9223B-18	Philip Melville
9/9/2025	8050 La Hona Road	E. COLI	Other	A	SM9223B-18	Philip Melville
9/9/2025	11 Pope Rd	COLIFORM	Other	A	SM9223B-18	Philip Melville
9/9/2025	11 Pope Rd	E. COLI	Other	A	SM9223B-18	Philip Melville
9/9/2025	8181 La Hona Road	COLIFORM	Other	A	SM9223B-18	Philip Melville
9/9/2025	8181 La Hona Road	E. COLI	Other	A	SM9223B-18	Philip Melville
9/9/2025	25 Memory Ln - Station 12	COLIFORM	Other	A	SM9223B-18	Philip Melville
9/9/2025	25 Memory Ln - Station 12	E. COLI	Other	A	SM9223B-18	Philip Melville
9/16/2025	Alpine Creek - Raw Water	Coliform	Other	141.4	SM9223B-18 (MPN)	Keefe Brennan
9/16/2025	Alpine Creek - Raw Water	E. Coli	Other	85.7	SM9223B-18 (MPN)	Keefe Brennan
9/16/2025	400 Ranch Rd. La Honda - Glenwood Boy	COLIFORM	Routine	A	SM9223B-18	Keefe Brennan
9/16/2025	400 Ranch Rd. La Honda - Glenwood Boy	E. COLI	Routine	A	SM9223B-18	Keefe Brennan
9/16/2025	8050 La Hona Road	COLIFORM	Other	A	SM9223B-18	Keefe Brennan
9/16/2025	8050 La Hona Road	E. COLI	Other	A	SM9223B-18	Keefe Brennan
9/16/2025	11 Pope Rd	COLIFORM	Other	A	SM9223B-18	Keefe Brennan
9/16/2025	11 Pope Rd	E. COLI	Other	A	SM9223B-18	Keefe Brennan
9/16/2025	8181 La Hona Road	COLIFORM	Other	A	SM9223B-18	Keefe Brennan
9/16/2025	8181 La Hona Road	E. COLI	Other	A	SM9223B-18	Keefe Brennan
9/16/2025	25 Memory Ln - Station 12	COLIFORM	Other	A	SM9223B-18	Keefe Brennan
9/16/2025	25 Memory Ln - Station 12	E. COLI	Other	A	SM9223B-18	Keefe Brennan
9/17/2025	25 Memory Ln - Station 12	COLIFORM	Other	A	SM9223B-18	Keefe Brennan
9/17/2025	25 Memory Ln - Station 12	E. COLI	Other	A	SM9223B-18	Keefe Brennan
9/17/2025	8181 La Hona Road	COLIFORM	Other	A	SM9223B-18	Keefe Brennan

1 = Routine
2 = Repeat
3 = Replacement
4 = Other
P = Present
A = Absent

Date of Report: October 06, 2025

Laboratory: BEI Analytical Laboratory (ELAP 3019)

Report Period: September, 2025

System Name: **La Honda Water System**

System Number: CA4100509

Collection Date	Site Name	Analyte	Sample Type	Result	Remarks	Sampler
9/17/2025	8181 La Hona Road	E. COLI	Other	A	SM9223B-18	Keefe Brennan
9/17/2025	11 Pope Rd	COLIFORM	Other	A	SM9223B-18	Keefe Brennan
9/17/2025	11 Pope Rd	E. COLI	Other	A	SM9223B-18	Keefe Brennan
9/17/2025	8050 La Hona Road	COLIFORM	Other	A	SM9223B-18	Keefe Brennan
9/17/2025	8050 La Hona Road	E. COLI	Other	A	SM9223B-18	Keefe Brennan

1 = Routine
2 = Repeat
3 = Replacement
4 = Other
P = Present
A = Absent