



**BRACEWELL ENGINEERING, INC.**

155 MAST STREET, UNIT 114, MORGAN HILL, CA 95037

(669) 258-5820 FAX (408) 498-7045

www.bracewellengineering.com

February 10, 2026

District Engineer  
State Water Resources Control Board-Division of Drinking Water  
850 Marina Bay Parkway, Building P, 2nd Floor  
Richmond, CA 94804

Re: January 2026 Monthly Report to the Office of Drinking Water  
La Honda Water System (County Service Area No. 7), No. CA4100509

Dear District Engineer:

Attached are the following:

1. Monitoring Report
  2. Lab Results
  3. Coliform Reporting Form
  4. Surface Water Reports
- Due to a leak at 8050 La Honda Rd., a shut-off notice was distributed. Once the leak was repaired, a boil water notice was issued and remained in effect until follow-up bacteriological samples were collected and confirmed absent of total coliforms and E. coli.
  - The monthly distribution system treated water bacteriological sample showed an absence of total coliforms and E. coli.
  - Chlorine residuals were maintained as required.
  - The minimum Disinfection CT ratio was 3.5 for a DDW required 1- log removal for Giardia.

Please do not hesitate to contact me if you have any questions.

Respectfully submitted,  
BRACEWELL ENGINEERING, INC.

Alan Bracewell  
Staff Engineer

Lhw Log Sheets

Location			Plant On	Raw Water	Raw Water	Treated Water	Backwash	Inlet	Inlet	Inlet	Inlet	Creek	Air	Air
Parameter			SW Plant	Tank	Flow	Average Flow	Flow	pH	Max Turbidity	Turbidity	Temp.	Water Level	Temp	Percip
frequency			daily	daily	calculation	calculation	calculation	weekly	daily	weekly	weekly	monthly	daily	daily
Units			Y/N	ft	gal/d	gal/d	gal/d	units	ntu	ntu	C	inches	C	%
Type				level	flow		flow		Analyzer	Grab	Grab	grab		
High Limit														
Low Limit														
Date	Initials	Time												
1/1/2026			Y		8,010	23,900	800							
1/2/2026			N		8,010	-	800							
1/3/2026			N		8,010	-	800							
1/4/2026			N		8,010	-	800							
1/5/2026			N		8,010	-	800							
1/6/2026			N		8,010	-	800							
1/7/2026	KB	1300	N	12.88	8,010	-	800							
1/8/2026			N		3	-	-							
1/9/2026			N		3	-	-							
1/10/2026			N		3	-	-							
1/11/2026			N		3	-	-							
1/12/2026			N		3	-	-							
1/13/2026			N		3	-	-							
1/14/2026			N		3	-	-							
1/15/2026			N		3	-	-							
1/16/2026			N		3	-	-							
1/17/2026			N		3	-	-							
1/18/2026			N		3	-	-							
1/19/2026			N		3	-	-							
1/20/2026	KB	1100	Y	10.02	3	35,750	-		14.87				14.8	37%
1/21/2026			Y		41,182	35,750	2,800							
1/22/2026			Y		41,182	35,750	2,800	8.6	4.55	3.80	11.8		10.1	38%
1/23/2026			Y		32,117	37,100	3,475							
1/24/2026			Y		32,117	37,100	3,475							
1/25/2026			N		32,117	-	3,475							
1/26/2026	KB	1045	Y	13.42	32,117	37,100	3,475		1.49				11.5	37%
1/27/2026			Y		55,745	48,750	4,200							
1/28/2026	KB	1240	Y	13.91	55,745	48,750	4,200	8.5	1.41	1.91	12	15	14.3	36%
1/29/2026			Y		48,022	43,360	4,500							
1/30/2026			Y		48,022	43,360	4,500							
1/31/2026			Y		48,022	43,360	4,500							
Min				10.02	3	-	-	8.5	1.409	1.91	11.8	15	10.1	36%
Max				13.91	55,745	48,750	4,500	8.6	14.87	3.8	12	15	14.8	38%
Average				12.56	16,855	15,162	1,516	8.6	5.581	2.86	11.9	15	12.7	37%
Total					522,501	470,030	47,000							





LHW

January

La Honda Water System

CHLORINE RESIDUAL	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	13460 Pescadero Creek	AA20901	1/26/26	0.24	mg/L		SM 4500-CI G	0.02	0.02	Routine
	14 Pope Rd	AA21100	1/22/26	1.00	mg/L		SM 4500-CI G	0.02	0.02	Other
		AA21099	1/21/26	0.84	mg/L		SM 4500-CI G	0.02	0.02	Other
				HIGH 1.00	AVG 0.92	LOW 0.84				
	8050 La Hona Road	AA21097	1/21/26	1.24	mg/L		SM 4500-CI G	0.02	0.02	Other
		AA21101	1/22/26	1.15	mg/L		SM 4500-CI G	0.02	0.02	Other
				HIGH 1.24	AVG 1.20	LOW 1.15				
	Trailer Park	AA21098	1/21/26	0.22	mg/L		SM 4500-CI G	0.02	0.02	Other
		AA21102	1/22/26	0.80	mg/L		SM 4500-CI G	0.02	0.02	Other
				HIGH 0.80	AVG 0.51	LOW 0.22				
COLIFORM MPN	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA20900	1/26/26	178.9	MPN/100mL		SM9223B-18 (MPN)	1.0	1.0	Other
COLIFORM PA	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	13460 Pescadero Creek	AA20901	1/26/26	A	P/A		SM9223B-18			Routine
	14 Pope Rd	AA21099	1/21/26	A	P/A		SM9223B-18			Other
		AA21100	1/22/26	A	P/A		SM9223B-18			Other
				HIGH	AVG	LOW				
	8050 La Hona Road	AA21097	1/21/26	A	P/A		SM9223B-18			Other
		AA21101	1/22/26	A	P/A		SM9223B-18			Other
				HIGH	AVG	LOW				
	Trailer Park	AA21098	1/21/26	A	P/A		SM9223B-18			Other
		AA21102	1/22/26	A	P/A		SM9223B-18			Other
				HIGH	AVG	LOW				
E COLI MPN	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA20900	1/26/26	42.6	MPN/100mL		SM9223B-18 (MPN)	1.0	1.0	Other
E COLI PA	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	13460 Pescadero Creek	AA20901	1/26/26	A	P/A		SM9223B-18			Routine
	14 Pope Rd	AA21100	1/22/26	A	P/A		SM9223B-18			Other
		AA21099	1/21/26	A	P/A		SM9223B-18			Other
				HIGH	AVG	LOW				
	8050 La Hona Road	AA21097	1/21/26	A	P/A		SM9223B-18			Other
		AA21101	1/22/26	A	P/A		SM9223B-18			Other
				HIGH	AVG	LOW				
	Trailer Park	AA21098	1/21/26	A	P/A		SM9223B-18			Other
		AA21102	1/22/26	A	P/A		SM9223B-18			Other
				HIGH	AVG	LOW				
NITRATE	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA20905	1/26/26	0.22	mg/L as N	10	SM 4500-NO3-D	0.05	0.20	
PFBS	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE

**January**

La Honda Water System

	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA21095	1/26/26	Not Detected	ng/L	500	E533	0.22	1.6	Grab
PFHXA	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA21095	1/26/26	Not Detected	ng/L	1000	E533	0.25	1.8	Grab
PFHXS	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA21095	1/26/26	Not Detected	ng/L	3	E533	0.27	1.6	Grab
PFOA	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA21095	1/26/26	Not Detected	ng/L	4	E533	0.31	1.8	Grab
PFOS	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA21095	1/26/26	Not Detected	ng/L	4	E533	0.33	1.7	Grab
UV254 PERF	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA21182	1/28/26	0.108	1/cm		SM 5910B			
	Treated Water	AA21183	1/28/26	0.057	1/cm		SM 5910B			

## Monthly Summary of Monitoring For Surface Water Treatment Regulations

System Name: La Honda Water System (CSA #7)

System Number: CA4100509

Treatment Plant Name: La Honda Water System (CSA #7)

Month: January Year: 2026

Treated Water Turbidities Every Four Hours (NTU)\*

Date	Peak Raw Water Turbidity	Peak Settled Water Turbidity	Midnight to 0400	0400 to 0800	0800 to Noon	Noon to 1600	1600 to 2000	2000 to Midnight	Average Treated Water	Minimum Ct. Ratio
1	5.93			0.08					0.08	3.5
2										
3										
4										
5										
6										
7										
8										
9										
10										
11										
12										
13										
14										
15										
16										
17										
18										
19										
20	14.80					0.16	0.08	0.07	0.10	5.7
21	3.59					0.08	0.09	0.13	0.10	3.9
22	2.28		0.10	0.12	0.22	0.10	0.08	0.08	0.12	5.2
23	1.54		0.08	0.07	0.07	0.08	0.07	0.07	0.08	5.2
24	1.39		0.08	0.07	0.07				0.08	4.4
25										
26	5.23					0.09	0.07	0.07	0.08	5.2
27	1.25			0.08	0.07	0.08	0.11	0.07	0.08	4.0
28	1.68		0.07	0.12	0.08	0.07	0.07	0.08	0.08	5.5
29	0.99		0.07	0.08	0.08	0.08	0.08	0.08	0.08	6.1
30	0.98		0.07	0.08	0.08	0.07	0.07	0.08	0.08	6.3
31	0.94		0.07	0.07	0.09	0.07	0.07	0.09	0.08	5.1
Ave.	3.38								0.08	3.5

\*If a continuous monitoring turbidimeter is used, determine discrete turbidity value for the same times during each 24-hour period

Total No. of Samples: 54 No. of Readings ≤ 0.3 NTU: 54

% Readings ≤ 0.3 NTU = [(No. Readings ≤ 0.3 NTU) / (Total No. Samples)] x 100 = 100%

Meets Standard (i.e. more than 95% of readings are ≤ 0.3 NTU) (Y/N)? Y

Percent reduction during the month = [(Average Raw NTU - Average Effluent NTU) / (Average Raw NTU)] x 100 = 97%

Meets Standard (i.e. reduction is greater than 80%) (Y/N)? Y

95th Percentile Value of all turbidity readings (95% of all turbidity readings are less than this value) 0.126

Incidents of turbidity greater than 1.0 NTU

Date of Incident				
Value				
Duration				

Total Number of incidents where turbidity is > 1.0 NTU: 0  
 Total Number of incidents where turbidity is > 5.0 NTU: 0  
 Meets Standards (i.e. NTU is not > 1.0 for more than eight consecutive hours) (Y/N)? Y

After placing a filter back into service after any interruption (e.g. backwashing), did the filter effluent comply with the following criteria:

- a. < 2.0 NTU after all events (Y/N)? Y
- b. < 1.0 NTU after 90% of events (Y/N)? Y
- c. < 0.5 NTU after 4 hours (Y/N)? Y

Indicate the date that the turbidimeters that are used for regulatory monitoring purposes were calibrated

Date	Which Turbidimeter	Standard used (primary/secondary)	Date	Which Turbidimeter	Standard Used (primary/secondary)
12/19/2024	Hach, raw wtr	0/20 Formazin	12/19/2024	Hach, treated	0/20 Formazin
3/28/2025	Hach, raw wtr	0/20 Formazin	3/28/2025	Hach, treated	0/20 Formazin
6/27/2025	Hach, raw wtr	0/20 Formazin	6/27/2025	Hach, treated	0/20 Formazin
9/29/2025	Hach, raw wtr	0/20 Formazin	9/29/2025	Hach, treated	0/20 Formazin
12/24/2026	Hach, raw wtr	0/20 Formazin	12/24/2026	Hach, treated	0/20 Formazin

Disinfection Process Data

Disinfectant residual type: free chlorine: X combined chlorine: \_\_\_\_\_ other (specify) \_\_\_\_\_

Incidents of chlorine residuals less than 0.2 ppm at the plant effluent:

Date of Incident			
Duration			
Date Dept. Notified			

Total number of incidents where residual is < 0.2 ppm: 0  
 Meets standard (i.e. not less than 0.2 ppm for more than four hours) (Y/N)? Y

No. of distribution system residual samples collected:	1
No of distribution system samples for HPC only:	
Total No. residual and/or HPC samples collected:	1
No. of samples with no detectable residual and HPC is not measured:	0
No. of samples with no residual and HPC > 500 CFU/ml:	
No. of samples for HPC only and HPC > 500 CFU/ml:	
Total No. Samples with no residual and/or HPC > 500 CFU/ml:	0

Compute V where  $V = [ 1 - ( \text{Total number of samples with no residual and/or HPC} > 500 ) / ( \text{Total number of residual and/or HPC samples collected} ) ] \times 100 =$  100%

Meets Standard (i.e V > 95%) (Y/N) Y





State of California  
Water Resources Control Board  
Division of Drinking Water  
**Coliform Reporting Form**

Date of Report: February 06, 2026

Laboratory: BEI Analytical Laboratory (ELAP 3019)

Report Period: January, 2026

System Name: **La Honda Water System**

System Number: **CA4100509**

Collection Date	Site Name	Analyte	Sample Type	Result	Remarks	Sampler
1/21/2026	8050 La Hona Road	COLIFORM	Other	A	SM9223B-18	Keefe Brennan
1/21/2026	8050 La Hona Road	E. COLI	Other	A	SM9223B-18	Keefe Brennan
1/21/2026	Trailer Park	COLIFORM	Other	A	SM9223B-18	Keefe Brennan
1/21/2026	Trailer Park	E. COLI	Other	A	SM9223B-18	Keefe Brennan
1/21/2026	14 Pope Rd	COLIFORM	Other	A	SM9223B-18	Keefe Brennan
1/21/2026	14 Pope Rd	E. COLI	Other	A	SM9223B-18	Keefe Brennan
1/22/2026	14 Pope Rd	COLIFORM	Other	A	SM9223B-18	Keefe Brennan
1/22/2026	14 Pope Rd	E. COLI	Other	A	SM9223B-18	Keefe Brennan
1/22/2026	8050 La Hona Road	COLIFORM	Other	A	SM9223B-18	Keefe Brennan
1/22/2026	8050 La Hona Road	E. COLI	Other	A	SM9223B-18	Keefe Brennan
1/22/2026	Trailer Park	COLIFORM	Other	A	SM9223B-18	Keefe Brennan
1/22/2026	Trailer Park	E. COLI	Other	A	SM9223B-18	Keefe Brennan
1/26/2026	Alpine Creek - Raw Water	Coliform	Other	178.9	SM9223B-18 (MPN)	Keefe Brennan
1/26/2026	Alpine Creek - Raw Water	E. Coli	Other	42.6	SM9223B-18 (MPN)	Keefe Brennan
1/26/2026	13460 Pescadero Creek	COLIFORM	Routine	A	SM9223B-18	Keefe Brennan
1/26/2026	13460 Pescadero Creek	E. COLI	Routine	A	SM9223B-18	Keefe Brennan

1 = Routine  
2 = Repeat  
3 = Replacement  
4 = Other  
P = Present  
A = Absent