



BRACEWELL ENGINEERING, INC.

155 MAST STREET, UNIT 114, MORGAN HILL, CA 95037

(669) 258-5820 FAX (408) 498-7045

www.bracewellengineering.com

August 3, 2026

District Engineer
State Water Resources Control Board-Division of Drinking Water
850 Marina Bay Parkway, Building P, 2nd Floor
Richmond, CA 94804

Re: June 2026 Monthly Report to the Office of Drinking Water
La Honda Water System (County Service Area No. 7), No. CA4100509

Dear District Engineer:

Attached are the following:

1. Monitoring Report
 2. Lab Results
 3. Coliform Reporting Form
 4. Surface Water Reports
 5. Quarterly Report for Disinfectant Residuals Compliance
 6. Quarterly TTHM & HAA5 Reports for Disinfection Byproducts Compliance
- The monthly distribution system treated water bacteriological sample showed an absence of total coliforms and E. coli.
 - Chlorine residuals were maintained as required.
 - The minimum Disinfection CT ratio was 4.4 for a DDW required 1- log removal for Giardia.
 - The quarterly disinfection byproducts monitoring was completed and the TTHM running annual average of 54.3 ug/L was in compliance with its MCL of 80 ug/L and the HAA5 running annual average of 54 ug/L was in compliance with its MCL of 60 ug/L.

Please do not hesitate to contact me if you have any questions.

Respectfully submitted,
BRACEWELL ENGINEERING, INC.

Alan Bracewell
Staff Engineer

Lhw Log Sheets

Location			Plant On	Raw Water	Raw Water	Treated Water	Backwash	Inlet	Inlet	Inlet	Inlet	Creek	Air	Air	Filter Inlet
Parameter			SW Plant	Tank	Flow	Average Flow	Flow	pH	Max Turbidity	Turbidity	Temp.	Water Level	Temp	Percip	Turbidity
frequency			daily	daily	calculation	calculation	calculation	weekly	daily	weekly	weekly	monthly	daily	daily	weekly
Units			Y/N	ft	gal/d	gal/d	gal/d	units	ntu	ntu	C	inches	C	%	ntu
Type				level	flow		flow		Analyzer	Grab	Grab	grab			Grab
High Limit															
Low Limit															
Date	Initials	Time													
6/1/2026			N		18,198	-	1,642								
6/2/2026			N		18,198	-	1,642								
6/3/2026			N		18,198	-	1,642								
6/4/2026			N		18,198	-	1,642								
6/5/2026			N		18,198	-	1,642								
6/6/2026			N		18,198	-	1,642								
6/7/2026			N		18,198	-	1,642								
6/8/2026	KB	1100	Y	13.11	18,198	43,760	1,642	8.6	1.57	1.84	14.4		14.7	32%	4.2
6/9/2026			Y		22,832	42,900	2,800								
6/10/2026			Y		22,832	42,900	2,800								
6/11/2026			Y		22,832	42,900	2,800								
6/12/2026			N		22,832	-	2,800								
6/13/2026			N		22,832	-	2,800								
6/14/2026			N		22,832	-	2,800								
6/15/2026	KB	1100	Y	14.27	22,832	42,900	2,800		0.41				18.9	30%	
6/16/2026			Y		40,522	47,467	4,667								
6/17/2026			Y		40,522	47,467	4,667								
6/18/2026	KB	945	Y	13.04	40,522	47,467	4,667	8.5	1.28	2.59	16.3		16.1	32%	1.7
6/19/2026			N		4,061	-	-								
6/20/2026			N		4,061	-	-								
6/21/2026			N		4,061	-	-								
6/22/2026	KB	930	Y	14.54	4,061	19,700	-	8.5	1.80	1.05	16		13.6	35%	0.43
6/23/2026			Y		11,854	32,700	1,600								
6/24/2026			Y		11,854	32,700	1,600								
6/25/2026			N		11,854	-	1,600								
6/26/2026			N		11,854	-	1,600								
6/27/2026			N		11,854	-	1,600								
6/28/2026			N		11,854	-	1,600								
6/29/2026	KB	900	Y	14.55	11,854	32,700	1,600	8.5	0.44	0.54	15	16"	13.4	35%	0.31
6/30/2026			Y		13,417	36,567	1,600								
Min				13.04	4,061	-	-	8.5	0.412	0.54	14.4	0	13.4	30%	0.31
Max				14.55	40,522	47,467	4,667	8.6	1.798	2.59	16.3	0	18.9	35%	4.2
Average				13.9	17,987	17,071	1,984	8.5	1.1	1.51	15		15.3	33%	1.66
Total					539,613	512,127	59,533								

Lhw Log Sheets

[illegible]

Lhw Log Sheets

Location	TW Storage Tank	TW Storage Tank	Aeration System	Aeration System	Aeration System	Routine Sample Site		
Parameter	pH	cl2 residual	Run in Hand	Pump Recirc Discharge	Recirc Pump Discharge	Cl2 Residual		
frequency	weekly	weekly	as needed	weekly	weekly	as needed		
Units	Units	ppm	Yes/No	min	min	mg/L		
Type						grab		
High Limit	8.5	2						
Low Limit	7.5	0.3						
Date								
6/1/2026			N					
6/2/2026			N			0.51		
6/3/2026			N					
6/4/2026			N					
6/5/2026			N					
6/6/2026			N					
6/7/2026			N					
6/8/2026			N					
6/9/2026			N					
6/10/2026			Auto					
6/11/2026	8.2	0.94		180	180	1.29		
6/12/2026								
6/13/2026								
6/14/2026								
6/15/2026			Y					
6/16/2026			Y					
6/17/2026			Y					
6/18/2026	8.3	0.91	Y			1.11		
6/19/2026			N					
6/20/2026			N					
6/21/2026			N					
6/22/2026	8.2	0.51	Y			0.23		
6/23/2026			Y					
6/24/2026			N					
6/25/2026			N					
6/26/2026			N					
6/27/2026			N					
6/28/2026			N					
6/29/2026			Y			0.58		
6/30/2026			Y					
Min	8.2	0.51		180	180	0.23		
Max	8.3	0.94		180	180	1.29		
Average	8.2	0.79		180	180	0.74		
Total								

LHW

June										La Honda Water System
CALIBRATION TURBIDITY	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA21893	6/29/26	Pass						
	Treated Water	AA21894	6/29/26	Pass						
CHLORINE RESIDUAL	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Old Chlorination Station- Sam McDonald Park	AA22587	6/22/26	0.23	mg/L		SM 4500-Cl G	0.02	0.02	Routine
COLIFORM MPN	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA22586	6/22/26	25.3	MPN/100mL		SM9223B-18 (MPN)	1.0	1.0	Other
COLIFORM PA	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Old Chlorination Station- Sam McDonald Park	AA22587	6/22/26	A	P/A		SM9223B-18			Routine
E COLI MPN	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA22586	6/22/26	1.0	MPN/100mL		SM9223B-18 (MPN)	1.0	1.0	Other
E COLI PA	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Old Chlorination Station- Sam McDonald Park	AA22587	6/22/26	A	P/A		SM9223B-18			Routine
UV254 PERF	SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
	Alpine Creek - Raw Water	AA22788	6/22/26	0.022	1/cm		SM 5910B			
	Treated Water	AA22789	6/22/26	0.010	1/cm		SM 5910B			

Monthly Summary of Monitoring For Surface Water Treatment Regulations

System Name: La Honda Water System (CSA #7)

System Number: CA4100509

Treatment Plant Name: La Honda Water System (CSA #7)

Month: June Year: 2026

Treated Water Turbidities Every Four Hours (NTU)*

Date	Peak Raw Water Turbidity	Peak Settled Water Turbidity	Midnight to 0400	0400 to 0800	0800 to Noon	Noon to 1600	1600 to 2000	2000 to Midnight	Average Treated Water	Minimum Ct. Ratio
1										
2										
3										
4										
5										
6										
7						0.06	0.06	0.06	0.06	
8	9.96		0.06	0.06	0.06	0.06	0.06	0.06	0.06	6.1
9	0.99		0.06	0.06	0.06	0.06	0.06	0.06	0.06	5.4
10	0.83		0.06	0.08	0.06	0.06			0.07	5.1
11	1.16									4.8
12										
13										
14						0.07	0.06	0.06	0.06	
15	10.21		0.07	0.06	0.06	0.07	0.06	0.05	0.06	6.1
16	1.00		0.07		0.05	0.06	0.06	0.07	0.06	4.7
17	2.16		0.06	0.06	0.07	0.06	0.05		0.06	5.2
18	1.45									5.7
19										
20										
21						0.07	0.06	0.05	0.06	
22	11.29		0.07	0.06	0.06	0.07	0.06	0.06	0.06	6.1
23	1.09		0.07	0.06					0.06	5.2
24	0.54									4.4
25										
26										
27										
28					0.06	0.06		0.06	0.06	
29	9.03		0.06		0.06	0.06	0.07	0.06	0.06	5.5
30	0.87									4.5
31										
Ave.	3.89								0.06	4.4

*If a continuous monitoring turbidimeter is used, determine discrete turbidity value for the same times during each 24-hour period

Total No. of Samples: 57 No. of Readings $\leq$ 0.3 NTU: 57

% Readings $\leq$ 0.3 NTU = [(No. Readings $\leq$ 0.3 NTU) / (Total No. Samples)] x 100 = 100%

Meets Standard (i.e. more than 95% of readings are $\leq$ 0.3 NTU) (Y/N)? Y

Percent reduction during the month = $\frac{[(\text{Average Raw NTU} - \text{Average Effluent NTU})]}{(\text{Average Raw NTU})} \times 100 =$ 98%

Meets Standard (i.e. reduction is greater than 80%) (Y/N)? Y

95th Percentile Value of all turbidity readings (95% of all turbidity readings are less than this value) 0.069

Incidents of turbidity greater than 1.0 NTU

Date of Incident				
Value				
Duration				

Total Number of incidents where turbidity is > 1.0 NTU: 0

Total Number of incidents where turbidity is > 5.0 NTU: 0

Meets Standards (i.e. NTU is not > 1.0 for more than eight consecutive hours) (Y/N)? Y

After placing a filter back into service after any interruption (e.g. backwashing), did the filter effluent comply with the following criteria:

a. < 2.0 NTU after all events (Y/N)? Y

b. < 1.0 NTU after 90% of events (Y/N)? Y

c. < 0.5 NTU after 4 hours (Y/N)? Y

Indicate the date that the turbidimeters that are used for regulatory monitoring purposes were calibrated

Date	Which Turbidimeter	Standard used (primary/secondary)	Date	Which Turbidimeter	Standard Used (primary/secondary)
12/19/2024	Hach, raw wtr	0/20 Formazin	12/19/2024	Hach, treated	0/20 Formazin
3/28/2025	Hach, raw wtr	0/20 Formazin	3/28/2025	Hach, treated	0/20 Formazin
6/27/2025	Hach, raw wtr	0/20 Formazin	6/27/2025	Hach, treated	0/20 Formazin
9/29/2025	Hach, raw wtr	0/20 Formazin	9/29/2025	Hach, treated	0/20 Formazin
12/24/2026	Hach, raw wtr	0/20 Formazin	12/24/2026	Hach, treated	0/20 Formazin
3/26/2026	Hach, raw wtr	0/20 Formazin	3/26/2026	Hach, treated	0/20 Formazin
6/29/2026	Hach, raw wtr	0/20 Formazin	6/29/2026	Hach, treated	0/20 Formazin

Disinfection Process Data

Disinfectant residual type: free chlorine: X combined chlorine: other (specify)

Incidents of chlorine residuals less than 0.2 ppm at the plant effluent:

Date of Incident				
Duration				
Date Dept. Notified				

Total number of incidents where residual is < 0.2 ppm: 0

Meets standard (i.e. not less than 0.2 ppm for more than four hours) (Y/N)? Y

No. of distribution system residual samples collected:	1
No of distribution system samples for HPC only:	
Total No. residual and/or HPC samples collected:	1
No. of samples with no detectable residual and HPC is not measured:	0
No. of samples with no residual and HPC > 500 CFU/ml:	
No. of samples for HPC only and HPC > 500 CFU/ml:	
Total No. Samples with no residual and/or HPC > 500 CFU/ml:	0

Compute V where $V = [1 - (\text{Total number of samples with no residual and/or HPC} > 500) / (\text{Total number of residual and/or HPC samples collected})] \times 100 =$ 100%

Meets Standard (i.e V > 95%) (Y/N) Y

Summary of Water Quality Complaints

General Complaints


Type of Complaint	Number	Corrective Actions Taken
Taste/Odor	0	
Color	0	
Turbidity	0	
Suspended Solids	0	
Other (describe)	0	

Reports of Gastrointestinal Illness (Attach additional sheets if necessary):

Person Reporting	Date	Corrective Actions Taken

Attach explanation of any failure of the performance standards or operating criteria and corrective action taken or planned

Signature:



Date:

7/10/2026

Quarterly Report for Disinfectant Residuals Compliance For Systems Using Chlorine or Chloramines

System Name: La Honda Water System (CSA #7) System No.: CA4100509

Calendar Year: 2026 Quarter: 2

1st Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
7/12/2010 Previous Year	April	1.10
	May	1.16
	June	1.09
	July	1.48
	August	1.63
	September	1.70
	October	1.29
	November	1.32
	December	1.06
Current Year	January	11
	February	5
	March	5
Running Annual Average (RAA):		1.22
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		Yes

2nd Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Previous Year	July	1.48
	August	1.63
	September	1.70
	October	1.29
	November	1.32
	December	1.06
Current Year	January	0.73
	February	0.61
	March	1.47
	April	14
	May	5
	June	6
Running Annual Average (RAA):		1.24
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		Yes

3rd Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Previous Yr	October	1.29
	November	1.32
	December	1.06
Current Year	January	0.73
	February	0.61
	March	1.47
	April	1.65
	May	1.33
	June	0.66
	July	
	August	
	September	
Running Annual Average (RAA):		
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		

4th Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Current Year	January	0.73
	February	0.61
	March	1.47
	April	1.65
	May	1.33
	June	0.66
	July	
	August	
	September	
	October	
	November	
	December	
Running Annual Average (RAA):		
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		

Comments:

Signature: 

Date: 7/10/2026

State of California
Water Resources Control Board
Division of Drinking Water
Coliform Reporting Form

Date of Report: July 06, 2026

Laboratory: BEI Analytical Laboratory (ELAP 3019)

Report Period: June, 2026

System Name: **La Honda Water System**

System Number: **CA4100509**

Collection Date	Site Name	Analyte	Sample Type	Result	Remarks	Sampler
6/22/2026	Alpine Creek - Raw Water	Coliform	Other	25.3	SM9223B-18 (MPN)	Keefe Brennan
6/22/2026	Alpine Creek - Raw Water	E. Coli	Other	1.0	SM9223B-18 (MPN)	Keefe Brennan
6/22/2026	Old Chlorination Station- Sam McDonald	COLIFORM	Routine	A	SM9223B-18	Keefe Brennan
6/22/2026	Old Chlorination Station- Sam McDonald	E. COLI	Routine	A	SM9223B-18	Keefe Brennan

1 = Routine
2 = Repeat
3 = Replacement
4 = Other
P = Present
A = Absent

Quarterly TTHM Report for Disinfection Byproducts Compliance (in µg/L or ppb)

System Name: La Honda Water System (CSA #7) System No.: CA4100509 Year: 2026 Quarter: 2

Year:	2022				2023				2024				2025				2026			
Quarter:	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Sample Date (month/date):	3/1	6/14	9/13	12/13	3/28	6/13	9/20	12/13	3/19	6/24	9/18	12/10	3/20	6/3	9/29	12/9	3/16	6/22		
Site 1	31.0	65.0	80.0	102.0	44.0	40.0	68.0	56.0	42.0	92.0	59.0	51.0	85.0	47.0	58.0	54.0	44.0	61.0		
Quarterly Average	31.0	65.0	80.0	102.0	44.0	40.0	68.0	56.0	42.0	92.0	59.0	51.0	85.0	47.0	58.0	54.0	44.0	61.0		
Running Annual Average	77.7	79.8	90.2	69.5	72.8	66.5	63.5	52.0	51.5	64.5	62.3	61.0	71.8	60.5	60.3	61.0	50.8	54.3		
Meets Standard (80 ug/L)?*	Yes	Yes	No	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes		
Number of Samples Taken	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		

Identify the sample locations in the table below.

Site	Sample Location
1	Old Chlorination Station
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	

Greg W. Brumwell
Signature

8/3/2026
Date

*If, during the first year of monitoring, any individual quarter's average will cause the running annual average of that system to exceed the standard, then the system is out of compliance at the end of that quarter.

Quarterly HAA5 Report for Disinfection Byproducts Compliance (in µg/L or ppb)

System Name: La Honda Water System System No.: CA4100509 Year: 2026 Quarter: 2

Year:	2022				2023				2024				2025				2026			
Quarter:	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Sample Date (month/date):	3/1	6/14	9/13	12/13	3/28	6/13	9/20	12/13	3/19	6/24	9/18	12/10	3/20	6/3	9/29	12/9	3/16	6/22		
Site 1	22.0	35.0	43.0	87.0	19.0	32.0	42.0	34.0	31.0	88.0	61.0	47.0	59.0	39.0	52.0	44.0	48.0	72.0		
Site 1 Sample																				
Site 3																				
Site 4																				
Site 5																				
Site 6																				
Site 7																				
Site 8																				
Site 9																				
Site 10																				
Site 11																				
Site 12																				
Quarterly Average	22.0	35.0	43.0	87.0	19.0	32.0	42.0	34.0	31.0	88.0	61.0	47.0	59.0	39.0	52.0	44.0	48.0	72.0		
Running Annual Average	41.5	42.1	53.0	46.8	46.0	45.3	45.0	31.8	34.8	48.8	53.5	56.8	63.8	51.5	49.3	48.5	45.8	54.0		
Meets Standard (60 ug/L)?*	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	No	Yes	Yes	Yes	Yes	Yes		
Number of Samples Taken	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1		

Identify the sample locations in the table below.

Site	Sample Location
1	Old Chlorination Station
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	


 Signature _____ Date 8/3/2026

*If, during the first year of monitoring, any individual quarter's average will cause the running annual average of that system to exceed the standard, then the system is out of compliance at the end of that quarter.