



BRACEWELL ENGINEERING, INC.
155 MAST STREET, UNIT 114, MORGAN HILL, CA 95037
(669) 258-5820 Emergency 831-673-5508
www.bracewellengineering.com

October 7, 2026

District Engineer
State Water Resources Control Board-Division of Drinking Water
850 Marina Bay Parkway, Building P, 2nd Floor
Richmond, CA 94804

Re: September 2026 Monthly Report to the Office of Drinking Water
La Honda Water System (County Service Area No. 7), No. CA4100509

Dear District Engineer:

Attached are the following:

1. Monitoring Report
 2. Lab Results
 3. Coliform Reporting Form
 4. Surface Water Reports
 5. Quarterly Report for Disinfectant Residuals Compliance
 6. Quarterly TTHM & HAA5 Reports for Disinfection Byproducts Compliance
- Due to a leak repair, a Shut off Notice and Boil Water Notice were distributed to affected homes, 8080 La Honda Rd and 8120 La Honda Rd.
 - o Follow up bacteriological samples were negative for total coliforms and E. coli.
 - The monthly distribution system treated water bacteriological sample showed an absence of total coliforms and E. coli.
 - Chlorine residuals were maintained as required.
 - The minimum Disinfection CT ratio was 3.8 for a DDW required 1- log removal for Giardia.
 - The quarterly disinfection byproducts monitoring was completed and the TTHM running annual average of 56.5 ug/L was in compliance with its MCL of 80 ug/L and the HAA5 running annual average of 52.5 ug/L was in compliance with its MCL of 60 ug/L.

Please do not hesitate to contact me if you have any questions.

Respectfully submitted,
BRACEWELL ENGINEERING, INC.

Alan Bracewell
Staff Engineer

Lhw Log Sheets

Location			Plant On	Raw Water	Raw Water Flow	Treated Water	Backwash	Inlet	Inlet	Inlet	Inlet	Creek	Air	Air
Parameter			SW Plant	Tank	Flow	Average Flow	Flow	pH	Max Turbidity	Turbidity	Temp.	Water Level	Temp	Percip
frequency			daily	daily	calculation	calculation	calculation	weekly	daily	weekly	weekly	monthly	daily	daily
Units			Y/N	ft	gal/d	gal/d	gal/d	units	ntu	ntu	C	inches	C	%
Type				level	flow		flow		Analyzer	Grab	Grab	grab		
High Limit														
Low Limit														
Date	Initials	Time												
9/1/2026			N		15,960	-	1,408							
9/2/2026			N		15,960	-	1,408							
9/3/2026			N		15,960	-	1,408							
9/4/2026			N		15,960	-	1,408							
9/5/2026			N		15,960	-	1,408							
9/6/2026			N		15,960	-	1,408							
9/7/2026			N		15,960	-	1,408							
9/8/2026	KB	1030	Y	14.78	15,960	42,950	1,408	8.6	1.00	2.27	16.2		33.2	72%
9/9/2026			Y		23,981	32,625	2,317							
9/10/2026			Y		23,981	32,625	2,317							
9/11/2026			N		23,981	-	2,317							
9/12/2026			N		23,981	-	2,317							
9/13/2026			Y		23,981	32,625	2,317							
9/14/2026	KB	1045	Y	13.72	23,981	32,625	2,317	8.7	0.36	0.70	15.3		18.1	32%
9/15/2026			N		250	-	-							
9/16/2026	JP/KB	1115	Y	14.48	250	600	-	8.6	1.15	0.50	15.4		15.6	33%
9/17/2026			Y		17,053	46,575	1,408							
9/18/2026			Y		17,053	46,575	1,408							
9/19/2026			Y		17,053	46,575	1,408							
9/20/2026			N		17,053	-	1,408							
9/21/2026			N		17,053	-	1,408							
9/22/2026			N		17,053	-	1,408							
9/23/2026			N		17,053	-	1,408							
9/24/2026			N		17,053	-	1,408							
9/25/2026			N		17,053	-	1,408							
9/26/2026			N		17,053	-	1,408							
9/27/2026			N		17,053	-	1,408							
9/28/2026	KB	1015	Y	13.45	17,053	46,575	1,408	8.4	0.89	0.55	15		13.3	35%
9/29/2026			Y		19,553	40,850	1,867							
9/30/2026			Y		19,553	40,850	1,867							
Min				13.45	250	-	-	8.4	0.359	0.5	15	0	13.3	32%
Max				14.78	23,981	46,575	2,317	8.7	1.15	2.27	16.2	0	33.2	72%
Average				14.11	17,193	14,735	1,527	8.6	0.848	1.01	15		20.1	43%
Total					515,803	442,050	45,800							

Lhw Log Sheets

[illegible]

Lhw Log Sheets

Location	TW Storage Tank	TW Storage Tank	TW Storage Tank	Aeration System	Aeration System	Aeration System	Routine Sample Site	
Parameter	Temp	pH	cl2 residual	Run in Hand	Pump Recirc Discharge	Recirc Pump Discharge	Cl2 Residual	
frequency	weekly	weekly	weekly	as needed	weekly	weekly	as needed	
Units	C	Units	ppm	Yes/No	min	min	mg/L	
Type							grab	
High Limit	17	8.5	2					
Low Limit	6.5	7.5	0.3					
Date								
9/1/2026				N				
9/2/2026				N				
9/3/2026				N				
9/4/2026				N				
9/5/2026				N				
9/6/2026				N				
9/7/2026				N				
9/8/2026				N			0.31	
9/9/2026				N				
9/10/2026				Y				
9/11/2026				Y				
9/12/2026				Y				
9/13/2026				Y				
9/14/2026	16.4	8.6	0.31	Y			1.93	
9/15/2026				N				
9/16/2026				N				
9/17/2026				N				
9/18/2026				N				
9/19/2026				N				
9/20/2026				N				
9/21/2026				N				
9/22/2026				N				
9/23/2026				N				
9/24/2026				N				
9/25/2026				N				
9/26/2026				N				
9/27/2026				N				
9/28/2026				Y			0.68	
9/29/2026				Y				
9/30/2026				Y				
Min	16.4	8.6	0.31		0	0	0.31	
Max	16.4	8.6	0.31		0	0	1.93	
Average	16.4	8.6	0.31				0.97	
Total								

CHLORINE RESIDUAL									
SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
400 Ranch	AA23606	9/14/26	1.93	mg/L		SM 4500-Cl G	0.02	0.02	Routine
8120 Lh Road	AA23695	9/9/26	1.16	mg/L		SM 4500-Cl G	0.02	0.02	Other
	AA23696	9/10/26	1.54	mg/L		SM 4500-Cl G	0.02	0.02	Other
HIGH 1.54 AVG 1.35 LOW 1.16									
COLIFORM MPN									
SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
Raw Water	AA23605	9/14/26	280.9	MPN/100mL		SM9223B-18 (MPN)	1	1	Other
COLIFORM PA									
SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
400 Ranch	AA23606	9/14/26	A	P/A		SM9223B-18			Routine
8120 Lh Road	AA23695	9/9/26	A	P/A		SM9223B-18			Other
	AA23696	9/10/26	A	P/A		SM9223B-18			Other
E COLI MPN									
SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
Raw Water	AA23605	9/14/26	23.5	MPN/100mL		SM9223B-18 (MPN)	1	1	Other
E COLI PA									
SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
400 Ranch	AA23606	9/14/26	A	P/A		SM9223B-18			Routine
8120 Lh Road	AA23695	9/9/26	A	P/A		SM9223B-18			Other
	AA23696	9/10/26	A	P/A		SM9223B-18			Other
TTHM									
SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
Oldcl2sta	AA23607	9/14/26	67	µg/L	80	EPA551.1			
CALIBRATION TURBIDITY									
SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
Raw Water	AA22943	9/28/26	Pass						
Treatedwtr	AA22944	9/28/26	Pass						
HALO ACETI									
SAMPLE POINT	SAMPLE ID	DATE	RESULT	UNIT	LIMIT	METHOD	DL	RL	TYPE
Oldcl2sta	AA23607	9/14/26	46	µg/L	60	EPA552	2	1	

Monthly Summary of Monitoring
For Surface Water Treatment Regulations

System Name: La Honda Water System (CSA #7)

System Number: CA4100509

Treatment Plant Name: La Honda Water System (CSA #7)

Month: September Year: 2026

Treated Water Turbidities Every Four Hours (NTU)*

Date	Peak Raw Water Turbidity	Peak Settled Water Turbidity	Midnight to 0400	0400 to 0800	0800 to Noon	Noon to 1600	1600 to 2000	2000 to Midnight	Average Treated Water	Minimum Ct. Ratio
1										
2										
3										
4										
5										
6										
7										
8	4.04					0.05	0.05	0.05	0.05	4.9
9	0.80					0.05	0.05	0.06	0.05	3.8
10	0.88		0.05	0.05	0.05				0.05	4.6
11										
12										
13	3.25					0.05	0.05	0.05	0.05	5.4
14	0.54		0.05	0.05	0.05				0.05	5.7
15										
16	2.66					0.05	0.05	0.05	0.05	5.9
17	0.65		0.05	0.05	0.05	0.05	0.05	0.05	0.05	5.5
18	0.65		0.05	0.05	0.05	0.05	0.05	0.05	0.05	5.4
19	0.70		0.05	0.05	0.04	0.05	0.05	0.04	0.05	5.8
20										
21										
22										
23										
24										
25										
26										
27										
28	8.30					0.05	0.05	0.05	0.05	6.2
29	0.64		0.04	0.05	0.05	0.04	0.05	0.04	0.05	4.5
30	0.64		0.04	0.05	0.05	0.04	0.05	0.05	0.05	4.9
31										
Ave.	1.98								0.05	3.8

*If a continuous monitoring turbidimeter is used, determine discrete turbidity value for the same times during each 24-hour period

Total No. of Samples: 51 No. of Readings $\leq$ 0.3 NTU: 51

% Readings $\leq$ 0.3 NTU = [(No. Readings $\leq$ 0.3 NTU) / (Total No. Samples)] x 100 = 100%

Meets Standard (i.e. more than 95% of readings are $\leq$ 0.3 NTU) (Y/N)? Y

Percent reduction during the month = $\frac{[(\text{Average Raw NTU} - \text{Average Effluent NTU})]}{(\text{Average Raw NTU})} \times 100 =$ 98%

Meets Standard (i.e. reduction is greater than 80%) (Y/N)? Y

95th Percentile Value of all turbidity readings (95% of all turbidity readings are less than this value) 0.054

Incidents of turbidity greater than 1.0 NTU

Date of Incident				
Value				
Duration				

Total Number of incidents where turbidity is > 1.0 NTU: 0

Total Number of incidents where turbidity is > 5.0 NTU: 0

Meets Standards (i.e. NTU is not > 1.0 for more than eight consecutive hours) (Y/N)? Y

After placing a filter back into service after any interruption (e.g. backwashing), did the filter effluent comply with the following criteria:

a. < 2.0 NTU after all events (Y/N)? Y

b. < 1.0 NTU after 90% of events (Y/N)? Y

c. < 0.5 NTU after 4 hours (Y/N)? Y

Indicate the date that the turbidimeters that are used for regulatory monitoring purposes were calibrated

Date	Which Turbidimeter	Standard used (primary/secondary)	Date	Which Turbidimeter	Standard Used (primary/secondary)
12/19/2024	Hach, raw wtr	0/20 Formazin	12/19/2024	Hach, treated	0/20 Formazin
3/28/2025	Hach, raw wtr	0/20 Formazin	3/28/2025	Hach, treated	0/20 Formazin
6/27/2025	Hach, raw wtr	0/20 Formazin	6/27/2025	Hach, treated	0/20 Formazin
9/29/2025	Hach, raw wtr	0/20 Formazin	9/29/2025	Hach, treated	0/20 Formazin
12/24/2026	Hach, raw wtr	0/20 Formazin	12/24/2026	Hach, treated	0/20 Formazin
3/26/2026	Hach, raw wtr	0/20 Formazin	3/26/2026	Hach, treated	0/20 Formazin
6/29/2026	Hach, raw wtr	0/20 Formazin	6/29/2026	Hach, treated	0/20 Formazin
9/28/2026	Hach, raw wtr	0/20 Formazin	9/28/2026	Hach, treated	0/20 Formazin

Disinfection Process Data

Disinfectant residual type: free chlorine: X combined chlorine: other (specify)

Incidents of chlorine residuals less than 0.2 ppm at the plant effluent:

Date of Incident				
Duration				
Date Dept. Notified				

Total number of incidents where residual is < 0.2 ppm: 0

Meets standard (i.e. not less than 0.2 ppm for more than four hours) (Y/N)? Y

No. of distribution system residual samples collected:	1
No of distribution system samples for HPC only:	
Total No. residual and/or HPC samples collected:	1
No. of samples with no detectable residual and HPC is not measured:	0
No. of samples with no residual and HPC > 500 CFU/ml:	
No. of samples for HPC only and HPC > 500 CFU/ml:	
Total No. Samples with no residual and/or HPC > 500 CFU/ml:	0

Compute V where $V = [1 - (\text{Total number of samples with no residual and/or HPC} > 500) / (\text{Total number of residual and/or HPC samples collected})] \times 100 = 100\%$

Meets Standard (i.e V > 95%) (Y/N) Y

Summary of Water Quality Complaints

General Complaints


Type of Complaint	Number	Corrective Actions Taken
Taste/Odor	0	
Color	0	
Turbidity	0	
Suspended Solids	0	
Other (describe)	0	

Reports of Gastrointestinal Illness (Attach additional sheets if necessary):

Person Reporting	Date	Corrective Actions Taken

Attach explanation of any failure of the performance standards or operating criteria and corrective action taken or planned

Signature:



Date:

10/9/2026

Quarterly Report for Disinfectant Residuals Compliance For Systems Using Chlorine or Chloramines

System Name: La Honda Water System (CSA #7) System No.: CA4100509

Calendar Year: 2026 Quarter: 3

1st Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
7/12/2010 Previous Year	April	1.10
	May	1.16
	June	1.09
	July	1.48
	August	1.63
	September	1.70
	October	1.29
	November	1.32
	December	1.06
Current Year	January	11
	February	5
	March	5
Running Annual Average (RAA):		1.22
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		Yes

2nd Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Previous Year	July	1.48
	August	1.63
	September	1.70
	October	1.29
	November	1.32
	December	1.06
Current Year	January	0.73
	February	0.61
	March	1.47
	April	14
	May	5
	June	6
Running Annual Average (RAA):		1.24
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		Yes

3rd Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Previous Yr	October	1.29
	November	1.32
	December	1.06
Current Year	January	0.73
	February	0.61
	March	1.47
	April	1.65
	May	1.33
	June	0.66
	July	4
	August	4
	September	5
		1.12
Running Annual Average (RAA):		1.08
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		Yes

4th Quarter		
Month	Number of Samples Taken	Monthly Ave. Chlorine Level (mg/L)
Current Year	January	0.73
	February	0.61
	March	1.47
	April	1.65
	May	1.33
	June	0.66
	July	0.66
	August	1.06
	September	1.12
	October	
	November	
	December	
Running Annual Average (RAA):		
Meets standard? (i.e. RAA ≤ MRDL of 4.0 mg/L as Cl ₂)		

Comments:

Signature: 

Date: 10/9/2026

Quarterly TTHM Report for Disinfection Byproducts Compliance (in µg/L or ppb)

System Name: La Honda Water System (CSA #7) System No.: CA4100509 Year: 2026 Quarter: 3

Year:	2022				2023				2024				2025				2026			
Quarter:	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Sample Date (month/date):	3/1	6/14	9/13	12/13	3/28	6/13	9/20	12/13	3/19	6/24	9/18	12/10	3/20	6/3	9/29	12/9	3/16	6/22	9/14	
Site 1	31.0	65.0	80.0	102.0	44.0	40.0	68.0	56.0	42.0	92.0	59.0	51.0	85.0	47.0	58.0	54.0	44.0	61.0	67.0	
Quarterly Average	31.0	65.0	80.0	102.0	44.0	40.0	68.0	56.0	42.0	92.0	59.0	51.0	85.0	47.0	58.0	54.0	44.0	61.0	67.0	
Running Annual Average	77.7	79.8	90.2	69.5	72.8	66.5	63.5	52.0	51.5	64.5	62.3	61.0	71.8	60.5	60.3	61.0	50.8	54.3	56.5	
Meets Standard (80 ug/L)?*	Yes	Yes	No	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	
Number of Samples Taken	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	

Identify the sample locations in the table below.

Site	Sample Location
1	Old Chlorination Station
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	


 Signature _____ Date 10/9/2026

*If, during the first year of monitoring, any individual quarter's average will cause the running annual average of that system to exceed the standard, then the system is out of compliance at the end of that quarter.


Quarterly HAA5 Report for Disinfection Byproducts Compliance (in µg/L or ppb)

System Name: La Honda Water System System No.: CA4100509 Year: 2026 Quarter: 3

Year:	2022				2023				2024				2025				2026			
Quarter:	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.	1st Qtr.	2nd Qtr.	3rd Qtr.	4th Qtr.
Sample Date (month/date):	3/1	6/14	9/13	12/13	3/28	6/13	9/20	12/13	3/19	6/24	9/18	12/10	3/20	6/3	9/29	12/9	3/16	6/22	9/14	
Site 1	22.0	35.0	43.0	87.0	19.0	32.0	42.0	34.0	31.0	88.0	61.0	47.0	59.0	39.0	52.0	44.0	48.0	72.0	46.0	
Site 1 Sample																				
Site 3																				
Site 4																				
Site 5																				
Site 6																				
Site 7																				
Site 8																				
Site 9																				
Site 10																				
Site 11																				
Site 12																				
Quarterly Average	22.0	35.0	43.0	87.0	19.0	32.0	42.0	34.0	31.0	88.0	61.0	47.0	59.0	39.0	52.0	44.0	48.0	72.0	46.0	
Running Annual Average	41.5	42.1	53.0	46.8	46.0	45.3	45.0	31.8	34.8	48.8	53.5	56.8	63.8	51.5	49.3	48.5	45.8	54.0	52.5	
Meets Standard (60 ug/L)?*	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	No	Yes	Yes	Yes	Yes	Yes	Yes	
Number of Samples Taken	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	

Identify the sample locations in the table below.

Site	Sample Location
1	Old Chlorination Station
2	
3	
4	
5	
6	
7	
8	
9	
10	
11	
12	



 Signature

10/9/2026

 Date

*If, during the first year of monitoring, any individual quarter's average will cause the running annual average of that system to exceed the standard, then the system is out of compliance at the end of that quarter.

State of California
Water Resources Control Board
Division of Drinking Water
Coliform Reporting Form

Date of Report: October 05, 2026

Laboratory: BEI Analytical Laboratory (ELAP 3019)

Report Period: September, 2026

System Name: **La Honda Water System**

System Number: **CA4100509**

Collection Date	Site Name	Analyte	Sample Type	Result	Remarks	Sampler
9/9/2026	8120 La Hona Road	COLIFORM	Other	A	SM9223B-18	Keefe Brennan
9/9/2026	8120 La Hona Road	E. COLI	Other	A	SM9223B-18	Keefe Brennan
9/10/2026	8120 La Honda Road	COLIFORM	Other	A	SM9223B-18	Keefe Brennan
9/10/2026	8120 La Honda Road	E. COLI	Other	A	SM9223B-18	Keefe Brennan
9/14/2026	Alpine Creek - Raw Water	Coliform	Other	280.9	SM9223B-18 (MPN)	Keefe Brennan
9/14/2026	Alpine Creek - Raw Water	E. Coli	Other	23.5	SM9223B-18 (MPN)	Keefe Brennan
9/14/2026	400 Ranch Rd. La Honda - Glenwood Boy	COLIFORM	Routine	A	SM9223B-18	Keefe Brennan
9/14/2026	400 Ranch Rd. La Honda - Glenwood Boy	E. COLI	Routine	A	SM9223B-18	Keefe Brennan

1 = Routine
2 = Repeat
3 = Replacement
4 = Other
P = Present
A = Absent